

Notes:
*See Demand Factor Table

- 1 RECEPTACLE MOUNTED ON SOPE OF ISLAND NOT MORE THAN 12" BELOW COUNTER TOP SURFACE.
- 2 ELECTRICAL CONTRACTOR TO SUPPLY AND INSTALL A DEDICATED 15AMP 120VAC CIRCUIT FOR SMOKE ALARMS IN DWELLING UNIT. CONNECT ALL SMOKE ALARMS IN RESPECTIVE UNIT TO THE DEDICATED CIRCUIT. REFER TO FIRE SUPPRESSION DRAWINGS FOR LOCATION AND WIRING OF SMOKE ALARMS.
- 3 ELECTRICAL CONTRACTOR TO SUPPLY AND INSTALL TWO (2) DPDT (DOUBLE POLE DOUBLE THROW) TRANSFER RELAY WITH 120V/120V, 6992-CON, 25AMP/120V/120V CONTACT RATINGS AND 1/2" NPT ENCLOSURE. THE TRANSFER RELAY SHALL BE INSTALLED IN THE ELECTRICAL DUXEL RECEPTACLE, SUCH THAT FAILURE OF UTILITY POWER WILL TRANSFER THE LOAD TO THE EMERGENCY GENERATOR. THE TRANSFER RELAY SHALL BE INSTALLED IN ACCORDANCE WITH REQUIREMENT OF THE ELECTRICAL PLAN, DESIGNATED FOR OPTIONAL, STANDARD, BYPASS, AND LOAD.
- 4 ELECTRICAL CONTRACTOR TO BE BOCCO - 22 SYSTEM PULSED MOUNTED OUTLETS, SUPPLY AND INSTALL READ POINT - SELF TEST SWITCH SYSTEM TO PROVIDE GROUND FAULT PROTECTION TO THE BOCCO - 22 SYSTEM PULSED MOUNTED OUTLETS. EXACT LOCATION OF THE READ POINT AND SELF TEST SWITCH (SWITCH) TO BE DETERMINED BY THE DESIGNER PRIOR TO INSTALLATION.
- 5 SUPPLY AND INSTALL WAIVED, UNOCCUPIED, IN INSTALLATION OF ADDRESSING RECEPTACLES. IN UNOCCUPIED RECEPTACLES, IT IS TO BE COMPLETED AND INSTALLED BY OTHERS.
- 6 EXHAUST FANS NOT REQUIRED TO BE CONTROLLED BY THE LIGHT SWITCH LOCATED IN THE

DRAWINGS ARE INTENDED TO SHOW GENERAL ARRANGEMENT, DESIGN AND EXTENT OF WORK AND ARE NOT TO BE USED FOR CONSTRUCTION. REFER TO THE CONTRACT FOR ADDITIONAL NOTATIONS EXCEPT WHERE DIMENSIONS ARE SHOWN. ELECTRICAL WORK IS SHOWN ON PLANS USING STANDARD INDUSTRY SYMBOLS. BEFORE ORDERING MATERIALS OR DOING ANY WORK, THE MEASURING PERSONNEL SHALL BE INSTRUCTED BY THE CONTRACTOR. THEREFORE, ANY SUBSTANTIAL DIFFERENCES BETWEEN DRAWINGS AND CONDITIONS IN THE FIELD SHALL BE SUBMITTED TO THE CONSTRUCTION MANAGER FOR CONSIDERATION. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS. ALL WORK PERFORMED INCLUDES LABOR, MATERIALS, AND EQUIPMENT REQUIRED TO INSTALL AND TEST ALL ELECTRICAL SYSTEMS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL ELECTRICAL SYSTEMS, INCLUDING, BUT NOT LIMITED TO, THESE DRAWINGS, AS SPECIFIED REFER TO ELECTRICAL CONSTRUCTION SCHEDULE FOR THE PROJECT. THE CONTRACTOR SHALL DISCONNECT REQUIREMENTS.

F. ALL EQUIPMENT SIZES AND POWER REQUIREMENTS FOR EQUIPMENT PROVIDED BY OTHERS.

ELECTRICAL CONDITIONS IN FINISHED SPACES SHALL BE CONCEALED COORDINATE WITH OTHER TRADES AND UTILITIES. CONCEALING AND CLEATING SPACES LOCATIONS OF ELECTRICAL JUNCTION BOXES IN FINISHED SPACES SHALL BE APPROVED BY ARCHITECT PRIOR TO ROUGH-IN.

F. REFER TO MECHANICAL AND PLUMBING PLANS FOR EXACT LOCATION OF HVAC/PLUMBING EQUIPMENT.

PROVIDE CONDUIT, WIRE AND J-BOXES FOR CONTRACTOR'S SHOWN LOCATIONS AND SIZES OF J-BOXES TO BE DETERMINED BY DETERMINING.

CONTRACTOR SHALL BE RESPONSIBLE FOR REPAIR OF ANY ELECTRICAL CIRCUITS DAMAGED BY CONTRACTOR'S WORK. CONTRACTOR SHALL BE RESPONSIBLE FOR REPAIRING ANY DAMAGE THERE WILL BE NO DISRUPTION OF SERVICE OUTSIDE OF CONSTRUCTION ZONE AREA. PROVIDE TAPEMER PROOF RECEIPTS IN RESIDENTIAL UNITS.

IF PROJECT INVOLVES FLOORING, THE CONTRACTOR SHALL PROVIDE STRUCTURAL DECK AND RAISED PAVES. SECURE, SLOPE, AND SLOPE CONDUIT PER CODE.

