


Olson Kundig

project: **SOMMET BLANC**
3300 Marsac Ave (B2 East Parcel)



revisions:

IFC Set 2 of 3
5/17/2024

TOWER A - LVL P2
ELECTRICAL LIGHTING
PLAN

E3.2A.02

A. DRAWINGS ARE INTENDED TO SHOW GENERAL ARRANGEMENT, DESIGN, AND EXTENT OF WORK AND ARE DIAGRAMMATIC. DRAWINGS ARE NOT INTENDED TO SHOW EXACT LOCATIONS EXCEPT WHERE DIMENSIONS ARE SHOWN. ELECTRICAL WORK IS SHOWN ON A STANDARD GRID. CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING MATERIALS IN COMMENCEMENT WITH WORK. VERIFY MEASUREMENTS PERTAINING THERETO AND ASSUME RESPONSIBILITY THEREFOR. ANY SUBSTANTIAL DIFFERENCES BETWEEN THE CONTRACT CONDITIONS AND THE ACTUAL CONDITIONS OF THE CONSTRUCTION MANAGER FOR CONSIDERATION BEFORE PROCEEDING WITH WORK.

B. WORK PERFORMED INCLUDES LABOR, MATERIALS, AND EQUIPMENT REQUIRED TO INSTALL ALL ELECTRICAL SYSTEMS AND EQUIPMENT. CONTRACTOR SHALL BE RESPONSIBLE TO PROVIDE EXT CABLES AND CONNECT EXT CABLES AND LUMINAIRES NOT AS EMERGENCY TO THE POWER SYSTEM. CONTRACTOR SHALL BE RESPONSIBLE FOR THE PLANS.

C. REFER TO LUMINAIRE SCHEDULE FOR INFORMATION.

D. FUTURE CABLE NUMBERS ARE SUBJECT TO CHANGE BY MANUFACTURER. VERIFY TO MANUFACTURER'S CATALOG FOR THE LATEST CABLE NUMBERS.

E. VERIFY EQUIPMENT SIZES AND POWER REQUIREMENTS FOR EQUIPMENT PROVIDED BY OTHERS.

F. ELECTRICAL CONDUITS IN FINISHED SPACES SHALL BE CONCEALED. COORDINATE WITH OTHER TRADES AND USE CHASES AND CEILING SPACES. LOCATIONS OF ELECTRICAL JUNCTION BOXES IN FINISHED SPACES SHALL BE APPROVED BY ARCHITECT PRIOR TO

1 LIGHT FIXTURE LOCATED IN CLOSETS ARE TO BE CONTROLLED BY CLOSET DOOR JAM SWITCH



1 TOWER A - PARKING LEVEL 2 ELECTRICAL LIGHTING RCP
SCALE: 1/8" = 1'-0"

