


Olson Kundig

Project: **SOMMET BLANC**
3300 Marsac Ave (B2 East Parcel)
Park City, Utah 84060



principal architect _____
project manager _____
drawn by _____
checked by Checker
job no. _____
date 05/17/2024

no.	date	t
-----	------	---

E3.3C.11

DRAWINGS ARE INTENDED TO SHOW GENERAL ARRANGEMENT, DESIGN, AND EXTENT OF WORK AND ARE DIAGRAMMATIC. DRAWINGS ARE NOT INTENDED TO SHOW EXACT "AS-BUILT" CONDITIONS. CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS AND DEVELOP PLANS USING STANDARD UTILITY SYMBOLS. BEFORE ORDERING MATERIALS OR COMMENCEMENT WITH WORK, VERIFY MEASUREMENTS RELATING THERETO AND ASSEMBLY OF ALL UTILITIES. CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS, DRAWINGS AND CONDITIONS IN THE FIELD SHALL BE SUBMITTED TO THE CONSTRUCTION MANAGER FOR CONSIDERATION BEFORE PROCEEDING WITH WORK.

CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS TO INSTALL A COMPLETE ELECTRICAL SYSTEM, AS INDICATED ON DRAWINGS AND SPECIFICATIONS. PROVIDE EXIST SIGNS AND CONNECT EXIST SIGNS AND LUMINAIRES NOTED AS EMERGENCY EQUIPMENT TO POWER SOURCE AND TO THE ELECTRICAL SYSTEM PLANS.

REFER TO LUMINAIRE SCHEDULE FOR INFORMATION.

EXISTING CABLE NUMBERS ARE SUBJECT TO CHANGE BY MANUFACTURER. VERIFY ALL CABLE NUMBERS AND CABLE TYPES PRIOR TO CONSTRUCTION.

VERIFY EQUIPMENT SIZES AND POWER REQUIREMENTS FOR EQUIPMENT PROVIDED BY OTHERS.

ELECTRICAL CONDITIONS IN FINISHED SPACES SHALL BE CONCEALED. COORDINATE WITH OTHER TRADES AND USE CHASES AND CEILING SPACES. LOCATIONS OF ELECTRICAL JUNCTION BOXES IN FINISHED SPACES SHALL BE APPROVED BY ARCHITECT PRIOR TO INSTALLATION.

NUMBERED NOTES:

