


Olson Kundig

project: **SOMMET BLANC**
3300 Marsac Ave (B2 East Parcel)



no.	date	by
-----	------	----

E3.4.N

DRAWINGS ARE INTENDED TO SHOW GENERAL ARRANGEMENT, DESIGN, AND EXIST OF WORK AND ARE DIAGNOSTIC. DRAWINGS ARE NOT INTENDED TO SHOW EXACT LOCATIONS EXCEPT WHERE DIMENSIONS ARE SHOWN. ELECTRICAL WORK IS SHOWN ON PLANS USING THE STANDARD ELECTRICAL SYMBOLS OF THE NATIONAL ELECTRICAL CONTRACTORS ASSOCIATION. VERIFY MEASUREMENTS PERTAINING THERETO AND ASSUME RESPONSIBILITY THEREFOR. ANY SUBSTANTIAL DIFFERENCES BETWEEN DRAWINGS AND CONDITIONS IN THE FIELD ARE TO BE SUBMITTED TO THE ARCHITECT FOR REVIEW AND APPROVAL BEFORE PROCEEDING WITH WORK.

VERIFY ALL WORKING CONDITIONS, LABOR, MATERIALS, AND EQUIPMENT REQUIRED TO INSTALL A COMPLETE ELECTRICAL SYSTEM AS INDICATED ON DRAWINGS AND SPECIFICATIONS. PROVIDE EXIST SIGNS AND CONTACT EXIST SIGNS AND LUMINAIRES NOTED AS EMERGENCY TO BE COVERED. PROVIDE ALL NECESSARY MATERIALS AND EQUIPMENT TO BE INSTALLED AND REFER TO LUMINAIRE SCHEDULE FOR INFORMATION.

FUTURE CATALOG NUMBERS ARE SUBJECT TO CHANGE BY MANUFACTURER. VERIFY FUTURE CATALOG NUMBERS FOR EQUIPMENT TO BE INSTALLED.

VERIFY EQUIPMENT SIZES AND POWER REQUIREMENTS FOR EQUIPMENT PROVIDED BY OTHERS.

ELECTRICAL CONDITIONS IN FINISHED SPACES SHALL BE CONCEALED. COORDINATE WITH OTHER TRADES AND USE CHASES AND CEILING SPACES. LOCATIONS OF ELECTRICAL JUNCTION BOXES IN FINISHED SPACES SHALL BE APPROVED BY ARCHITECT PRIOR TO ROUGH-IN.

COORDINATE REMOTE DERIVATIVE ROUTING LOCATIONS WITH ARCHITECT PRIOR TO ROUGH-IN. PROVIDE LUMINAIRE VOUCHER TO ARCHITECT AND OWNER PRIOR TO PURCHASE AND INSTALLATION TYPE FOR ALL UNIT LIGHTING.

- 1 LUTRON WIRELESS PICO CONTROL SWITCH IS TO BE SUPPLIED AND INSTALLED FOR SHADE CONTROL.
- 2 SUPPLY AND INSTALL LUTRON IN-CLOSET ARE TO BE CONTROLLED BY CLOSET DOOR JAMB SWITCH.
- 3 SUPPLY AND INSTALL LUTRON RASD RASD SYSTEM TO PROVIDE PARTIAL LIGHTING CONTROL IN THE RESIDENTIAL MASTER BEDROOM (SYSTEM TO BE USED IN 1) AND ALL ROOMS WITH MORE THAN THREE (3) LIGHTING CONTROL ZONES ARE TO BE CONTROLLED BY THE LUTRON RASD RASD SYSTEM ALL ROOMS WITH ONE OR LIGHTING CONTROL ZONES ARE TO BE CONTROLLED BY THE LUTRON RASD RASD SYSTEM.
- 4 REFER TO ARCHITECTURAL DRAWINGS AND ELEVATIONS FOR EXACT DIMENSION AND MOUNTING LOCATION OF LIGHT FIXTURE TYPE L04. COORDINATE WITH MILLWORK CONTRACTOR PRIOR TO INSTALLATION.
- 5 SUPPLY AND INSTALL CEILING MOUNTED JUNCTION BOX COMPLETE WITH CAPPED LIGHTING CIRCUIT WIRING AND ALL NECESSARY LUTRON WIRING.

