


Olson Kundig

project: **SOMMET BLANC**
9300 Marsac Ave (B2 East Parcel)
Park City, Utah 84060



MEP Engineer
WSP USA
1001 Fourth Ave., Suite 3100
Seattle, WA 98154

revisions:

no.	date	by
-----	------	----

E3.4.R

DRAWINGS ARE INTENDED TO SHOW GENERAL ARRANGEMENT, DESIGN, AND EXTENT OF WORK AND ARE DIAGNOSTIC. DRAWINGS ARE NOT INTENDED TO SHOW EXACT LOCATIONS OF WORK. WHEN DIMENSIONS ARE NOT SHOWN, WORK SHALL BE ON PLANS TO THE STANDARD INDUSTRY SYMBOLS. BEFORE ORDERING MATERIALS OR COMMENCEMENT OF WORK, VERIFY MEASUREMENTS PERTAINING THERE TO AND ASSUME RESPONSIBILITY THEREFOR. THE SUBMITTER OF THE DRAWINGS SHALL BE RESPONSIBLE FOR THE FIELD. SHALL BE SUBMITTED TO THE CONSTRUCTION MANAGER FOR CONSIDERATION BEFORE PROCEEDING WITH WORK.

EXISTING AND NEW ELECTRICAL LABOR, MATERIALS, AND EQUIPMENT REQUIRED TO INSTALL A COMPLETE ELECTRICAL SYSTEM AS INDICATED ON DRAWINGS AND SPECIFICATIONS. PROVIDE EXIST SIGNS AND CONNECT EXIST SIGNS AND LUMINAIRES NOTED AS EMERGENCY TO EMERGENCY POWER SOURCE AND TO EMERGENCY LIGHTING.

REFER TO LUMINAIRE SCHEDULE FOR INFORMATION.

EXISTING LUMINOUS NUMBERS ARE SUBJECT TO CHANGE BY MANUFACTURER. VERIFY FACTURE NUMBER AND DATE FOR EACH LUMINAIRE.

VERIFY EQUIPMENT SIZES AND POWER REQUIREMENTS FOR EQUIPMENT PROVIDED BY OTHERS.

ELECTRICAL CONDUITS IN FINISHED SPACES SHALL BE CONCEALED. COORDINATE WITH OTHER TRADES AND USE CHASES AND CEILING SPACES. LOCATIONS OF ELECTRICAL JUNCTION BOXES IN FINISHED SPACES SHALL BE APPROVED BY ARCHITECT PRIOR TO ROUGH-IN.

COORDINATE REMOTE DRIVER MOUNTING LOCATIONS WITH ARCHITECT PRIOR TO ROUGH-IN. THE LUMINAIRE SHALL BE INSTALLED IN ACCORDANCE WITH THE OWNER'S PRIOR TO PURCHASE AND INSTALLATION TYPE AND ALL UNIT LIGHTING.

1 LIGHT FIXTURE LOCATED IN CLOSETS ARE TO BE CONTROLLED BY CLOSET DOOR JAM SWITCH

