


Olson Kundig

project:
SOMMET BLANC
3300 Marsac Ave (B2 East Parcel)
Bark City, Utah 84060



no	date	by
----	------	----

no.	date	by
-----	------	----

IFC Set 3 of 3
05/31/2024

ELECTRICAL
SCHEDULES

E6.13C

BRANCH PANEL: OLP-8C1

Wired ELEC 0902

Main Bus: 225 A

MCB: 225 A

Voltage: 120/208 VAC

AIC Rating: 10 kA

Fed From: OLP-1C1

Wire: 4W + G

Enclosure: NEMA 1

Type: COPPER

Mounting: SURFACE MOUNTED

Neutral Bus: YES

Ground Bus: YES

Isolated Ground Bus: NO

200% Neutral: NO

Feed Through Lugs: NO

CKT	Circuit Description	Load Classification	Trip	Poles	A	B	C	Poles	Trip	Load Classification	Circuit Description	CKT		
1	LEVEL UNIT- WINE FRIDGE	RCPTS	20 A	1	800 VA	800 VA			1	20 A	RCPTS	LEVEL 7 UNIT- WINE FRIDGE	2	
3	LEVEL UNIT- WINE FRIDGE	RCPTS	20 A	1		800 VA	800 VA		1	20 A	RCPTS	LEVEL 7 UNIT- WINE FRIDGE	4	
5	LEVEL UNIT- MISC RCPT	RCPTS	20 A	1					1	20 A	RCPTS	LEVEL 7 UNIT- MISC RCPT	6	
7	LEVEL UNIT- MISC RCPT	RCPTS	20 A	1	500 VA	500 VA			1	20 A	RCPTS	LEVEL 7 UNIT- MISC RCPT	8	
9	Spare	--	20 A	1		0 VA	0 VA	--	1	20 A	--	Spare	10	
11	Spare	--	20 A	1					1	20 A	--	Spare	12	
13	Spare	--	20 A	1	0 VA	0 VA			1	20 A	--	Spare	14	
15	LEVEL UNIT- WINE FRIDGE	RCPTS	20 A	1		800 VA	800 VA		1	20 A	RCPTS	LEVEL 8 UNIT- WINE FRIDGE	16	
17	LEVEL UNIT- WINE FRIDGE	RCPTS	20 A	1			800 VA	800 VA	1	20 A	RCPTS	LEVEL 8 UNIT- MISC RCPT	18	
19	LEVEL UNIT- WINE FRIDGE	RCPTS	20 A	1	500 VA	0 VA			1	20 A	--	Spare	20	
21	LEVEL UNIT- WINE FRIDGE	RCPTS	20 A	1					1	20 A	--	Spare	22	
23	LEVEL UNIT- MISC RCPT	RCPTS	20 A	1		500 VA	0 VA	0 VA	0 VA	1	20 A	--	Spare	24
25	Spare	--	20 A	1		0 VA	0 VA		1	20 A	--	Spare	26	
27	Spare	--	20 A	1		0 VA	0 VA		1	20 A	--	Spare	28	
29	Spare	--	20 A	1					1	20 A	--	Spare	30	
31	Spare	--	20 A	1	0 VA	0 VA			1	20 A	--	Spare	32	
33	Spare	--	20 A	1		0 VA	0 VA		1	20 A	--	Spare	34	
35	LEVEL UNIT- WINE FRIDGE	RCPTS	20 A	1			800 VA	0 VA	1	20 A	--	Spare	36	
37	LEVEL UNIT- WINE FRIDGE	RCPTS	20 A	1	800 VA	0 VA			1	20 A	--	Spare	38	
39	LEVEL 6 UNIT- MISC RCPT	RCPTS	20 A	1		500 VA	0 VA		2	30 A	MISC	SPD	40	
41	LEVEL 6 UNIT- MISC RCPT	RCPTS	20 A	1				500 VA	0 VA	--	--	--	42	
Total Load:					4200 VA	4200 VA	3900 VA							
					35 A		33 A							

OLP-8C1 LOAD SUMMARY

Load Classification	Connected Load	*Demand Factor	Estimated Demand	Panel Totals
RCPTS	12300 VA		1150 VA	
MISC	0 VA		0 VA	
				Total Conn. Load: 12300 VA
				Total Est. Demand: 11150 VA
				Total Conn. : 36 A
				Total Est. Demand: 31 A

Notes:

*See Demand Factor Table