


NOTES:	COORDINATE WITH OTHER TRADES SUBMITTAL PACKAGE AND FILL THE PART-B OF THE SCHEDULE BASED ON THE MANUFACTURERS DATA. THE SCHEDULES SHALL BE SUBMITTED ALONG WITH THE PANEL BOARDS, DISCONNECTS AND FUSE SUBMITTAL PACKAGE. CONFIRM THE OVER CURRENT PROTECTION, WIRE AND CONDUIT SIZE SHALL BE IN ACCORDANCE WITH THE MANUFACTURERS ELECTRICAL REQUIREMENT. THE ELECTRICAL SUBMITTALS WILL NOT BE APPROVED WITHOUT THE FILLED PART-B SCHEDULE.
--------	---

REFER TO WIRING SCHEDULE FOR BRANCH CIRCUIT REQUIREMENTS
SIZES BASED ON COPPER CONDUCTORS
* VALUE ASSUMES A SERVICE FACTOR OF AT LEAST 1.15.

REFER TO WIRING SCHEDULE FOR BRANCH CIRCUIT REQUIREMENTS
SIZES BASED ON COPPER CONDUCTORS
* VALUE ASSUMES A SERVICE FACTOR OF AT LEAST 1.15.



+1 206 624 5670 olsonkundig.com

project: **SOMMET BLANC**
3300 Marsac Ave (B2 East Parcel)



Landscape Architect
EPG Design
6949 South High Tech Drive, Suite 100
Midvale, Utah 84047

Code Consultant
Halmes

600 1st Avenue, Suite 200A
Seattle, WA 98104

Vertical Transportation Consultation

Structural Engineer

Lighting Designer
O-

Building Envelope Consultant

Accessibility Consultant
Studio Briefing

MEP Engineer
WSP USA
1001 Fourth Ave., Suite 3100
Seattle, WA 98154

revisions:

no.	date	by
-----	------	----

E7.01AB

