

- KEYNOTES
- 1 FIRE ALARM TERMINAL CABINET WITH 2-HR RATED SHIRT ACCESSIBLE VIA 2-HR RATED ACCESS PANEL. COORDINATE INSTALLATION AND ACCESS WITH DIVISION 25. TRANSITION FROM 2-HR DC TO RPL CABLE IN EMT AT THIS POINT.
 - 2 2-HR DC SLC AND NAC FROM FDC TO 2-HR RATED SHIRT. ROUTING SHOWN FOR CONCEPTUAL PURPOSES ONLY.
 - 3 DEDICATED SPEAKER CIRCUIT (2-HR DC) TO STAIR SPEAKERS. TRANSITION TO RPL IN EMT AT FIRST DEVICE.

