

- | | |
|---|---|
| 1 | FIRE ALARM TERMINAL CABINET WITHIN 2-HR RATED SHIELD ACCESSIBLE VIA 2-HR RATED ACCESS PANEL. COORDINATE INSTALLATION AND ACCESS WITH DIVISION 26. |
| 2 | NO FATC THIS LEVEL. |
| 3 | ACCESSORY CABINET ENCLOSURE FOR SMOKE CONTROL FAN INTERFACE LOCATED IN 2-HR RATED ENCLOSURE ADJACENT TO FAN VFD (FOR FANS SPF-B-P1-1 THRU SPF-B-P1-4). REFER TO DETAIL 5 ON FAT-01 FOR ADDITIONAL INFORMATION. MODULES SHALL BE CONNECTED TO 2-HR DEDICATED SLC FROM BUILDING B FACU. |

159 South Jackson St., Suite 600
Seattle, Washington 98104 USA
+1 206 624 5670 olsenkundig.com

project: **SOMMET BLANC - AB**
DEER VALLEY, UTAH

FA2.2B.03

