



	LH	LIGHT HAZARD: SYSTEM PROVIDING A DENSITY OF 10 GRANSQ/FT. OVER DESIGN AREA OF 1,300 SQ. FT. WITH 100 GPM HOSE ALLOWANCE.
	RES	RESIDENTIAL HAZARD: SYSTEM PROVIDING A DENSITY OF 10 GRANSQ/FT. OVER DESIGN AREA OF 4 SPRINKLERS, WITH 100 GPM HOSE ALLOWANCE.
	OH1	ORDINARY HAZARD GROUP 1: SYSTEM PROVIDING A DENSITY OF 15 GRANSQ/FT. OVER DESIGN AREA OF 1,300 SQ. FT. WITH 250 GPM HOSE ALLOWANCE.
	OH2	ORDINARY HAZARD GROUP 2: SYSTEM PROVIDING A DENSITY OF 20 GRANSQ/FT. OVER DESIGN AREA OF 1,500 SQ. FT. WITH 250 GPM HOSE ALLOWANCE.
	EX1	EXTRA HAZARD GROUP 1: SYSTEM PROVIDING A DENSITY OF 30 GRANSQ/FT. OVER DESIGN AREA OF THE ENTIRE ROOM WITH 500 GPM HOSE ALLOWANCE.
	NS	NON-SPRINKLERED AREA

FP1.03