



	LIGHT HAZARD: SYSTEM PROVIDING A DENSITY OF 0.15 GPMSQFT. OVER DESIGN AREA OF 1,500 SQ. FT. WITH 100 GPM HOSE ALLOWANCE
	RESIDENTIAL HAZARD: SYSTEM PROVIDING A DENSITY OF 0.10 GPMSQFT. OVER DESIGN AREA OF 4 SPRINKLERS. WITH 100 GPM HOSE ALLOWANCE
	ORDINARY HAZARD GROUP 1: SYSTEM PROVIDING A DENSITY OF 0.15 GPMSQFT. OVER DESIGN AREA OF 1,500 SQ. FT. WITH 200 GPM HOSE ALLOWANCE
	ORDINARY HAZARD GROUP 2: SYSTEM PROVIDING A DENSITY OF 0.20 GPMSQFT. OVER DESIGN AREA OF 1,500 SQ. FT. WITH 250 GPM HOSE ALLOWANCE
	EXTRA HAZARD GROUP 1: SYSTEM PROVIDING A DENSITY OF 0.30 GPMSQFT. OVER DESIGN AREA OF THE ENTIRE ROOM WITH 500 GPM HOSE ALLOWANCE
	NON-SPRINKLERED AREA

FP1.06