


SHEET NOTES:

- A. REFER TO M2.4 SERIES FOR ENLARGED PLANS.
B. FIREPLACE FLUE ROUTING SHOW FOR REFERENCE. REFER TO ENLARGED UNIT PLANS FOR ROUTING AND SIZING DETAIL.
C. MECHANICAL EQUIPMENT SHOW FOR REFERENCE. REFER TO ENLARGED UNIT PLANS FOR DETAIL.
D. ALL DUCTING AND EQUIPMENT LOCATED IN THE GARAGE SHALL BE INSTALLED THRU TO UNDERSIDE OF THE SLAB TO MAINTAIN 6" CLEARANCES FOR VEHICLES.
E. ARCHITECT SHALL PROVIDE 1'-SOFT N/A OPENINGS IN ALL FULL HEIGHT, NON-RATED WALLS FOR RETURN AIRS IF NO DUCT TRAFFER IS SHOWN.
F. ALL EQUIPMENT, INSULATION, WIRING, AND INFRASTRUCTURE IN THE PLENUM SHALL BE PLENUM RATED RETURN DUCT SHALL NOT BE INSTALLED ABOVE FINISHED HARD-UP CEILINGS.
G. PROVIDE BUTTON TYPE TEMPERATURE SENSOR IN PUBLIC AREAS. SEE DETAIL-13, SHEET M-04
H. PROVIDE 1/2" RIGID CABLE DAMPER OPERATOR IN DIFFUSERS ABOVE HARD-UP CEILINGS. SEE DETAIL-9, SHEET M-04.
I. SHEET M-05

NUMBERED NOTES:

- 1 PROVIDE CONTINUOUS PLENUM ON UNDERSIDE OF FLOOR GRILL WITHIN INTERSTITIAL SPACE FOR CONNECTION TO DUCT FROM BELOW. PROVIDE REMOTE DAMPER ACTUATORS ACCESSIBLE FROM FLOOR GRILL
- 2 ARCHITECT SHALL PROVIDE RATED ENCLOSURE WITH DUCT INSTALLED TIGHT TO UNDERSIDE OF SLAB TO PREVENT THE NEED FOR FSDS



Reserved for permit stamp

159 South Jackson St, Suite 600
Seattle, Washington 98104 USA
Tel: 206 624 5670 info@nundig.com

Olson Kundig

project: **SOMMET BLANC**
9300 Marsac Ave (B2 East Parcel)
Park City, Utah 84060



Aspen Group USA, LLC
PO Box 980022
Park City, Utah 84098

Pool Consultant
Cloward H2O
2696 N University Ave, Suite 290
Provo, UT 84604

Landscape Architect
EPG Design
6949 South High Tech Drive, Suite 100
Midvale, Utah 84047

Friday Group
88 Mainelli Road
Middlebury, VT

Code Consultant
Holmes
600 1st Avenue, Suite 200
Seattle, WA 98104

Fire Protection Engineer
Jensen Hughes
One Research Drive, Suite 305C
Westborough, MA 01581

Vertical Transportation Consultant
Lorch Bates
19515 North Creek Parkway, Suite 304
Bothell, WA 98011

Structural Engineer
Magnusson Klemencic Associates
1301 5th Ave., Suite 3200
Seattle, WA 98101

Lighting Designer
O-
1319 SE MLK Blvd, Suite 210
Portland, Oregon 97219

Building Envelope Consultants
RDH
2101 N 34th St
Seattle, WA 98103

Accessibility Consultant
Studio Pacifica
2144 Westlake Ave N, Suite F
Seattle, WA 98109

MEP Engineer
WSP USA
1001 Fourth Ave., Suite 3100
Seattle, WA 98154

principal architect _____
project manager _____
drawn by _____
checked by Checker
job no. _____
date 5/17/2024

revisions;

no.	date	by
-----	------	----

IFC Set 2 of 3
5/17/2024

MECHANICAL PLANS
TOWER AB LOBBY

M2.2AB.11

