



**NUMBERED NOTES:**

- 1 5"O CONCENTRIC FLUE TO GAS FIREPLACE. PROVIDE ORTAL IN-LINE 180 POWERVENT (120V/55A).
- 2 RANGE HOOD EXHAUST FAN TO BE INTEGRAL WITH RANGE SPECIFIED BY ARCHITECT. INTERLOCK CONTROL WITH MUA-A.
- 3 ELECTRICAL RADIANT FLOOR TO BE PROVIDED IN MASTER BATHROOM. SEE ELECTRICAL DRAWINGS.
- 4 2" RETURN AIR SLOT
- 5 OWNER OPTION: PROVIDE 120V/61A CONNECTION FOR APPLARE 800 HUMIDIFIER DOWNSTREAM OF FAN COIL UNIT. REFER TO ELECTRICAL DRAWINGS FOR DETAILS. REFER TO PLUMBING DRAWINGS FOR 1/2" CW CONNECTION. ROUTE 3/4" CD TO NEAREST SINK TAILPIECE. REFER TO DETAILS MS 048 & MS 0412 FOR INSTALLATION CONNECTION.
- REMOVE SOUND LINING FROM FAN COIL AND PROVIDE PRICE RSP 3-0" SOUND ATTENUATOR WITH A MINIMUM INSERTION LOSS OF:
- |    |     |     |     |      |      |      |      |
|----|-----|-----|-----|------|------|------|------|
| 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 |
| 0  | 4   | 6   | 8   | 9    | 7    | 9    | 8    |
- CONFIRM WITH OWNER AND ARCHITECT PRIOR TO PROVIDING HUMIDIFIER.
- 6 OWNER OPTION: PROVIDE 208V/61A CONNECTION FOR APPLARE 800 HUMIDIFIER DOWNSTREAM OF FAN COIL UNIT. REFER TO ELECTRICAL DRAWINGS FOR DETAILS. REFER TO PLUMBING DRAWINGS FOR 1/2" CW CONNECTION. ROUTE 3/4" CD TO NEAREST SINK TAILPIECE. REFER TO DETAILS MS 048 & MS 0412 FOR INSTALLATION CONNECTION.
- REMOVE SOUND LINING FROM FAN COIL AND PROVIDE PRICE RSP 3-0" SOUND ATTENUATOR WITH A MINIMUM INSERTION LOSS OF:
- |    |     |     |     |      |      |      |      |
|----|-----|-----|-----|------|------|------|------|
| 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 |
| 0  | 4   | 6   | 8   | 9    | 7    | 9    | 8    |
- CONFIRM WITH OWNER AND ARCHITECT PRIOR TO PROVIDING HUMIDIFIER.
- 7 PLAT DIFFUSERS TO FIT BENTH LOWERED SLAB
- 8 SNOOMELL OVERSIDE SWITCH. COORDINATE EXACT LOCATION WITH ARCHITECT.
- 9 CONNECT 4"O TO DRYER
- 10 LOCATION OF STEAM GENERATOR FOR DUCT HUMIDIFIER. CONFIRM EXACT LOCATION WITH ARCHITECT PRIOR TO INSTALLING.

