

- A. CONFIRM EXACT LOCATION OF ALL WALL DEVICES WITH ARCHITECTURAL ELEVATIONS.
- B. CONFIRM ALL CEILING AND WALL ACCESS DOORS WITH ARCHITECTURAL RCPS AND WALL ELEVATIONS.
- C. REFER TO M3-2A-01 THROUGH M3-2C-01 FOR RADIANT FLOOR HWS/R PIPING ROUTING AND SIZING.
- D. PROVIDE 1-INCH ACOUSTIC LINING FOR ENTIRETY OF MAIN DUCT RUN OFF FAN COIL.
- E. ROUTE 3/4" CONDENSATE DRAINS FROM FCUS TO NEAREST TAILPIECE.

1 5"O CENTRIC FLOW TO GAS FRIEPLATE. PROVIDE ORIT. IN LINE 180 POWERPOINT (200)/15A.  
2 RANGE HOOD EXHAUST FAN TO BE NEGRAI. WITH RANGE SPECIFIED BY THE ARCHTCT.  
3 INTERLOCK COIL WITH INTERLOCK. ROUTE 3/4" CD TO NEAREST SINK TAILPIPE. REFER TO  
4 PROVIDE APPLARE 800 HUMIDIFIER. ASSUME 3" CW, 3/4" CD TO NEAREST SINK TAILPIPE. AND  
5 1201 ELECTRICAL CONNECTION.  
6 2" RETURN AIR-LOOT  
7 OWNER OPTION: PROVIDE 12016/141 CONNECTION FOR APPLARE 800 HUMIDIFIER DOWNSTREAM  
8 OF FAN COIL UNIT. REFER TO ELECTRICAL DRAWINGS FOR DETAIL. REFER TO PLUMBING  
9 INSTRUCTIONS FOR 12" CD. PROVIDE 3/4" CD TO NEAREST SINK TAILPIPE. REFER TO  
10 DETAILS MS.048 & MS.042 FOR INSTALLATION CONNECTION.  
11  
12 REMOVE SLOD LING FROM FCU AND PROVIDE PRICE RSP 3" STD ATTENUATOR WITH  
13 A MINIMUM INSERTION LOSS OF:

|    |     |     |     |      |      |      |
|----|-----|-----|-----|------|------|------|
| 65 | 120 | 250 | 500 | 1000 | 2000 | 4000 |
| 0  | 4   | 8   | 8   | 7    | 9    | 8    |

REMOVE SOUND LINING FROM FCU AND PROVIDE PRICE RSP 3'-0" SOUND ATTENUATOR WITH A MINIMUM INSERTION LOSS OF:

|    |     |     |     |      |      |      |      |
|----|-----|-----|-----|------|------|------|------|
| 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 |
| 0  | 4   | 6   | 8   | 7    | 9    | 8    | 0    |

[illegible]

SCALE: 1/4" = 1'-0"

reserved for permit stamp

Olson Kundaig



**ASPEN** GROUP

## M2.4.O

