

1 TOWER B - ROOF MECHANICAL PIPIING PLAN SCALE: 1/8" = 1'-0"

## SHEET NOTES:

COILS.

A. ALL CHILLED WATER AND HOT WATER BRANCH PIPING SHALL BE SIZED AT 1" FOR ALL FAN COIL UNITS UNLESS OTHERWISE NOTED. B. REFER TO MANUFACTURER SPECIFICATIONS FOR REFRIGERANT PIPING SIZING FOR SPLIT SYSTEM FAN

(23)	
22	
21	
20	
19	
18	
17	
15	
14	

No. 12196 - 222/28 MATTHE			
% WILLIAM MGSINE®			
Reserved for permit stamp			
Olson Kundig 159 South Jackson St, Suite 600 Seattle, Washington 98104 USA +1 206 624 5670 olsonkundig.com	project: SOMMET BLANC 9300 Marsac Ave (B2 East Parcel) Park City, Utah 84060		
ASPEN GROUP Aspen Group USA, LLC PO Box 980022 Park City, Utah 84098			
Pool Consultant Cloward H20         2696 N University Ave, Suite 290 Provo, UT 84604         Landscape Architect EPG Design 6949 South High Tech Drive, Suite 100 Midvale, Utah 84047         Specifications Writer Friday Group 88 Mainelli Road Middlebury, VT         Code Consultant Holmes 600 1st Avenue, Suite 200A Seattle, WA 98104         Fire Protection Engineer Jensen Hughes One Research Drive, Suite 305C Westborough, MA 01581         Vertical Transportation Consultant Lerch Bates 19515 North Creek Parkway, Suite 304 Bothell, WA 98011         Structural Engineer Magnusson Klemencic Associates 1301 5th Ave, Suite 3200 Seattle, WA 98101         Lighting Designer O 1319 SE MLK Blvd, Suite 210 Portland, Oregon 97219         Building Envelope Consultant RDH 2101 N 34th St Seattle, WA 98103         Accessibility Consultant Studio Pacifica 2144 Westlake Ave N, Suite F Seattle, WA 98109         MEP Engineer WSP USA 1001 Fourth Ave., Suite 3100 Seattle, WA 98154			
principal architect   project manager   drawn by			
IFC Set 2 of 3 5/17/2024			
TOWER B - ROOF MECHANICAL PIPING PLAN M3.2B.R			

N 0 2' 4' 6' 8' 16' 24'

2]