


1 TOWER C - PARKING LEVEL MECHANICAL PIPING PLAN


SCALE: 1/8" = 1'-0"

## **SHEET NOTES:**


- A. ALL BRANCH PIPING SIZE OF CHILLED WATER AND HOT WATER TO FAN COIL UNIT IS 1" UNLESS OTHERWISE NOTED.
- B. ALL BRANCH PIPING SIZE OF HOT WATER TO FAN POWERED TERMINAL UNIT IS 1" UNLESS OTHERWISE NOTED.
- C. ROUTE 3/4" CONDENSATE FROM FPTS AND FCUS TO NEAREST SINK TAILPIECE PER DETAIL M5.06/8.




1 REFER TO MANUFACTURER SPECIFICATIONS FOR EXACT PIPING SIZES.



Reserved for permit stamp



Kundig



Pool Consultant
Cloward H20
2696 N University Ave, Suite 290
Provo, UT 84604

<u>Landscape Architect</u> **EPG Design**6949 South High Tech Drive, Suite 100
Midvale, Utah 84047

Specifications Writer Friday Group 88 Mainelli Road Middlebury, VT

Code Consultant
Holmes
600 1st Avenue, Suite 200A
Seattle, WA 98104 Fire Protection Engineer
Jensen Hughes
One Research Drive, Suite 305C
Westborough, MA 01581

Vertical Transportation Consulatant Lerch Bates 19515 North Creek Parkway, Suite 304 Bothell, WA 98011

Structural Engineer

Magnusson Klemencic Associates
1301 5th Ave, Suite 3200
Seattle, WA 98101


<u>Lighting Designer</u> **O-**1319 SE MLK Blvd, Suite 210 Portland, Oregon 97219

Building Envelope Consultant RDH 2101 N 34th St Seattle, WA 98103

Accessibility Consultant
Studio Pacifica
2144 Westlake Ave N, Suite F
Seattle, WA 98109 MEP Engineer
WSP USA
1001 Fourth Ave., Suite 3100
Seattle, WA 98154

> principal architect\_\_\_\_\_ project manager\_\_\_\_\_

checked by <u>Checker</u> job no. date 05/17/2024



no. date

IFC Set 2 of 3 05/17/2024

TOWER C - LVL P1 MECHANICAL PIPING PLAN M3.2C.01

