



ORTAL EXHAUST FAN CONFIGURATION SCALE: NTS



6 SNOWMELT LOOP CONNECTION SCALE: NTS













- SUPPLY AND RETURN PIPING MANIFOLD WITH SHUT-OFF VALVES, THERMOMETERS

- DRAINS AND VENTS (TYP)

-SNOWMELT OR RADIANT FLOOR MANIFOLD (TYP)

- CHARGING CONNECTION

SIGHT GLASS

— HOUSEKEEPING PAD



(3) TERMINATION EXAMPLES - FOR 5-16 TERMINATIONS FOR MINIMAL FOOTPRINT - VERTICAL TERMINATIONS MUST BE STAGGERED IN HEIGHT. DISTANCE BETWEEN VERTICAL TERMINATIONS = 12" WHEN IN STAGGERED LAYOUT.

DISTANCE BETWEEN HORIZONTAL TERMINATIONS = 3' 0"

SCALE: NTS

