
TOWER C-UNIT L

SCALE: 1/4" = 1'-0"




- 1 PROVIDE ½" G, LOW PRESSURE REGULATOR, AND SHUT-OFF VALVE FOR FIREPLACE.
- 2 STEAM SHOWER GENERATOR UNIT: PROVIDE 1/2" CW WITH SHUT-OFF VALVE AND ROUTE DRAIN TO LAV TAILPEACE.
- PROVIDE ½" HW, ½" CW, 1-1/2" VENT AND 2" SAN FOR BAR SINK. PROVIDE ½" HW AND DRAIN WITH AIR GAP FOR DISHDRAWER TYPE DISHWASHER.
- 4 PROVIDE 3/4" G, LOW PRESSURE REGULATOR, AND SHUT-OFF VALVE FOR FIRE PIT.
- 5 PROVIDE 3/4" G, LOW PRESSURE REGULATOR, AND SHUT-OFF VALVE FOR BBQ.
- 6 PROVIDE HOT & COLD WALL HYDRANT FOR FILL FOR HOT TUB. OWNER OPTION: PROVIDE 1/2" CW TO DUCT HUMIDIFIERS. SEE MECHANICAL PLANS FOR LOCATIONS. CONFIRM WITH OWNER PRIOR TO PROVIDING.

NUMBERED NOTES:

Kundig

Reserved for permit stamp



Pool Consultant
Cloward H20
2696 N University Ave, Suite 290
Provo, UT 84604 <u>Landscape Architect</u> **EPG Design**6949 South High Tech Drive, Suite 100
Midvale, Utah 84047

Specifications Writer Friday Group 88 Mainelli Road Middlebury, VT

Code Consultant
Holmes
600 1st Avenue, Suite 200A
Seattle, WA 98104 <u>Fire Protection Engineer</u> **Jensen Hughes**One Research Drive, Suite 305C

Westborough, MA 01581

Vertical Transportation Consulatant Lerch Bates 19515 North Creek Parkway, Suite 304 Bothell, WA 98011

Structural Engineer

Magnusson Klemencic Associates
1301 5th Ave, Suite 3200
Seattle, WA 98101

<u>Lighting Designer</u> **O-**1319 SE MLK Blvd, Suite 210 Portland, Oregon 97219

Building Envelope Consultant RDH 2101 N 34th St Seattle, WA 98103 Accessibility Consultant
Studio Pacifica
2144 Westlake Ave N, Suite F
Seattle, WA 98109

MEP Engineer
WSP USA
1001 Fourth Ave., Suite 3100
Seattle, WA 98154

principal architect _____ project manager_____ drawn by_____

checked by <u>GM</u> job no. 2021-0595 date 5/17/2024

no. date

IFC Set 2 of 3 5/17/2024

UNIT PLAN - TOWER C-UNIT L

P2.4.L