

SHEAR W	SHEAR WALL VERTICAL REINFORCING SCHEDUL		
MARK	REINFORCING	REMARKS	
V1	#6 @ 12"	EF	
V2	#7 @ 12"	EF	
V3	#8 @ 12"	EF	
V4	#7 @ 6"	EF	
V5	#9 @ 12"	EF	

SHEAR WALL HORIZONTAL REINFORCING SCHEDULE

MARK	REINFORCING	REMARKS
H1	#5 @ 12"	EF
H2	#6 @ 12"	EF
H3	#7 @ 12"	EF
H6	#5 @ 6"	(3) LAYERS
H7	#5 @ 6"	(4) LAYERS



4 WEST SHEAR WALL ELEVATION

REFERENCE DRAWINGS

- DRAWING INDEX, ABBREVIATIONS, LEGENDS, GENERAL NOTES S0.XX S1.XX LOAD DIAGRAMS
- S2.XX PLANS
- S3.XX ELEVATIONS S4.XX TYPICAL DETAILS AND SCHEDULES
- CONCRETE SECTIONS AND DETAILS S5.XX STEEL SECTIONS AND DETAILS S6.XX

<u>NOTES</u>

- 1. CORE WALL OPENINGS REMAIN THE SAME SIZE AS THE DIMENSIONED OPENING BELOW, UNLESS NOTED OTHERWISE.
- 2. WALL OPENINGS AND SLEEVE PENETRATIONS NOT SPECIFICALLY INDICATED ON THE STRUCTURAL DRAWINGS SHALL BE APPROVED BY THE STRUCTURAL ENGINEER PRIOR TO CONSTRUCTION.
- 3. FOUNDATION DOWELS SHALL MATCH SIZE AND SPACING OF SHEAR WALL VERTICAL BARS ABOVE. EXTEND DOWELS TO BOTTOM OF FOUNDATION WITH 90 DEGREE HOOK.
- 4. VERTICAL REINFORCEMENT RETAINS THE SAME MARK AS FOR THE STORY BELOW, UNLESS NOTED OTHERWISE.
- 5. LAP VERTICAL REINFORCEMENT Lsb, UNLESS NOTED OTHERWISE. AT THE CONTRACTOR'S OPTION VERTICAL REINFORCEMENT MAY BE SPLICED AT INTERMEDIATE LEVELS, UNLESS NOTED OTHERWISE.
- 6. LAP HORIZONTAL REINFORCEMENT Lsbt, UNLESS NOTED OTHERWISE. WHERE LAPS NOT EXPLICITLY SHOWN IN SHEAR WALL SECTIONS, CONTRACTOR SHALL SUBMIT ANY ADDITIONAL LAP LOCATIONS FOR REVIEW BY THE ENGINEER.
- 7. SEE SHEAR WALL SECTIONS FOR ADDITIONAL REINFORCEMENT NOT SHOWN ON SHEAR WALL ELEVATIONS.
- 8. 1 A INDICATES A CONCRETE COUPLING BEAM. SEE "TYPICAL CONCRETE COUPLING BEAM DETAILS AND SCHEDULES" FOR REINFORCEMENT. WHERE NO COUPLING BEAM IS CALLED OUT BETWEEN STACKED OPENINGS, SEE "TYP SLAB WITHOUT COUPLING BEAM AT STACKED WALL OPENINGS" DETAIL.
- 9. CONCRETE PLACED IN THE COUPLING BEAMS, INCLUDING THROUGHOUT THE SLAB DEPTH, SHALL MEET THE SAME SPECIFICATIONS AS FOR THE SHEAR WALLS. SEE GENERAL NOTES FOR CRITERIA.
- 10. SEE GENERAL NOTES FOR REINFORCEMENT THAT SHALL MEET SPECIAL DUCTILE QUALITY CRITERIA.



