7 SHEAR WALL SECTION - LEVEL 4 TO ROOF

NOTES:

- ALL HOOPS AND CROSSTIES SHALL BE #5 A615 GRADE 80 PLACED AT 6-INCH VERTICAL SPACING, UNLESS NOTED OTHERWISE. CROSSTIES WITH 90 DEGREE HOOKS SHALL HAVE THE CONSECUTIVE CROSSTIES ALTERNATED END-FOR-END ALONG THE LONGITUDINAL REINFORCEMENT.
- 2. CONCRETE COVER TO REINFORCEMENT IS 1-INCH.
- 3. BAR SIZE OF ADDED VERTICAL BARS TO MATCH SIZE AND GRADE OF ADJACENT REINFORCEMENT, UNLESS NOTED OTHERWISE. AT CORNERS, MATCH REINFORCEMENT SIZE OF THE LARGER OF THE TWO WALLS.

SHEAR WALL NOTES



Reserved for permit stamp

Kundiç

MAGNUSSON KLEMENCIC ASSOCIATES Structural + Civil Engineers Seattle Chicago www.mka.com 206 292 1200

> principal architect__ job no.<u>20052</u> date 05/17/2024

IFC SET 2 OF 3 05/17/2024

TOWER B SOUTH CORE WALL SECTIONS

S3.B21

