




1. ALL HOOPS AND CROSSTIES SHALL BE #5 A615 GRADE 80 PLACED AT 6-INCH VERTICAL SPACING, UNLESS NOTED OTHERWISE. CROSSTIES WITH 90 DEGREE HOOKS SHALL HAVE THE CONSECUTIVE CROSSTIES ALTERNATED END-FOR-END ALONG THE LONGITUDINAL REINFORCEMENT.
2. CONCRETE COVER TO REINFORCEMENT IS 1-INCH.
3. BAR SIZE OF ADDED VERTICAL BARS TO MATCH SIZE AND GRADE OF ADJACENT REINFORCEMENT, UNLESS NOTED OTHERWISE. AT CORNERS, MATCH REINFORCEMENT SIZE OF THE LARGER OF THE TWO WALLS.

SHEAR WALL SECTION NOTES



Olson Kundig

project: **SOMMET BLANC - ABC**

**MAGNUSSON
KLEMENCIC**
ASSOCIATES
Structural + Civil Engineers
Seattle Chicago
www.mka.co
206.292.1200

CONCLUSIONS

TOWER C SHEAR
WALL SECTIONS

S3.C10