



159 South Jackson St., Suite 600
Seattle, Washington 98104 USA

Olson Kundig

object: SOMMET BLANC - ABC
SOMMET BLANC - ABC

**MAGNUSSON
KLEMENCIC**
ASSOCIATES
Structural + Civil Engineers
Seattle Chicago
www.mka.com
206.469.1000



1. STAGGERED CONDITION APPLIES TO ALL TOP BARS EXCEPT HOOKED BARS AT SLAB EDGES

9



1. THIS DETAIL ONLY APPLIES TO MILD REINFORCED SLABS

(13)



1. LOCATE ALL CONSTRUCTION JOINTS WITHIN THE MIDDLE THIRD OF THE SPAN. SUBMIT LOCATIONS OF ALL CONSTRUCTION JOINTS TO ENGINEER FOR REVIEW AND ACCEPTANCE PRIOR TO FORMING.
2. PROVIDE #4x5'-0" @ 24" CENTERED ACROSS CONSTRUCTION JOINT AT LOCATIONS WHERE TOP SLAB REINFORCING IS NOT SPECIFIED PER PLAN.

(17)



1. SHORE SLAB UNTIL CLOSURE STRIP REACHES 28 DAY DESIGN STRENGTH.
2. REINFORCING IN OPPOSITE DIRECTION IS PER PLANS.

18



1. WHEN NO EXTENT LINES EXIST AT MILD SLAB CAMBER, A SINGLE HIGH POINT AT MID-BAY IS INDICATED. THE SURROUNDING SLAB SLOPES AWAY TOWARD THE ADJACENT COLUMNS OR WALLS.

(19)

principal architect _____
project manager _____
drawn by _____
checked by _____
job no. 20052
date 04/08/2024

revisions:

2	04/08/2024	IFC SET 1 OF 3
1	11/18/2022	95% CD

no. _____ date _____

ISSUED FOR CONSTRUCTION
SET 1 OF 3

04/08/2024

TYPICAL MILD SLAB DETAILS

S4.04