

RCP GENERAL NOTES

1. SPOT ELEVATIONS ARE RELATIVE TO FINISH FLOOR LEVEL AND INDICATE BOTTOM OF FINISH

2. ALL CEILINGS 9'-0" AFF U.N.O.

3. ALL CEILINGS ASSEMBLY C11 U.N.O.

4. ALL DIMENSIONS TO FACE OF FINISH U.N.O. 5. SEE CONCRETE PLANS FOR EXTENT OF CONCRETE SLABS AND BEAMS 6. OCCUPIABLE SPACES, HABITABLE SPACES AND CORRIDORS SHALL HAVE A CEILING HEIGHT OF NOT LESS THAN 7 FEET AND 6 INCHES. BATHROOMS, TOILET ROOMS, KITCHENS, STORAGE ROOMS AND LAUNDRY ROOMS SHALL HAVE A CEILING HEIGHT OF NOT LESS THAN

7. SEE SHEET A0.10 AND A0.11 FOR FLOOR/CEILING ASSEMBLIES. 8. SEE ELECTRICAL AND LIGHTING DRAWINGS FOR LIGHTING LAYOUTS AND ADDITIONAL INFORMATION NOT SHOWN ON ARCHITECTURAL RCP DRAWINGS. 9. REFER TO MECHANICAL FOR SPRINKLER AND EXTINGUISHER TYPE AND FOR LOCATIONS. 10. ALL WALL-MOUNTED FIXTURES IN COMMON AREAS AND AMENITY LEVELS TO PROJECT 4" MAXIMUM FROM WALL FACE OR BE 6'-8" MINIMUM TO THE UNDERSIDE OF THE FIXTURE AFF. 11. SMOKE DETECTORS SHALL BE LOCATED A MINIMUM OF 3'-0" FROM SUPPLY AIR DIFFUSERS. 12. CENTER SPRINKLER HEAD LOCATIONS BETWEEN LIGHTING FIXTURES AND/OR SMOKE DETECTORS, TYPICAL. LOCATION AND SPACING TO BE DETERMINED WITH APPROVED SHOP DRAWINGS. PROVIDE SIDE ARMS WHERE HEADS AND OTHER CEILING FIXTURES MAY BE IN CONFLICT. ALIGN ALL HEADS AND FIXTURES ORTHAGONALLY. 13. FIRE-RATED CEILINGS SHALL ALWAYS BE CONTINUOUS ABOVE DROPPED CEILINGS OR SOFFITS WITH FASTENING AND JOINT TAPE AS REQUIRED FOR SPECIFIED RATING. 14. FIRE-RATED CEILINGS SHALL ALWAYS BE CONTINUOUS OVER CHASES/FURRED-OUT SPACES TO PREVENT THE WALL CAVITY FROM COMMUNICATING WITH THE FLOOR/CEILING CAVITY. FIRESTOP ALL PENETRATIONS OF FIRE-RATED FLOOR/CEILING ASSEMBLIES. 15. SEE MECHANICAL DRAWINGS FOR DUCT ROUTING. SEE MECHANICAL DRAWINGS FOR

ADDITIONAL INSULATION REQUIREMENTS AT DUCTS. 16. CEILING ACCESS PANELS ARE REQUIRED AT ALL DAMPERS, VALVES, TELECOM ACCESS POINTS, AND SOME MECHANICAL EQUIPMENT. COORDINATE LOCATIONS PRIOR TO INSTALLATION OF ANY OF THESE SYSTEMS

ELECTRICAL AND MECHANICAL INFORMATION ARE SHOWN FOR COORDINATION PURPOSES. REFER TO MECHANICAL DRAWINGS AND ELECTRICAL DRAWINGS FOR GENERAL INFORMATION AND LOCATIONS.

WOOD CEILING

RCP LEGEND

HATCH PATTERN INDICATE EXTENT OF CEILING TYPES REFER TO CEILING ASSEMBLY FOR DETAIL INFORMATION

SUSPENDED GYPSUM WALL BOARD STONE TILE ACOUSTICAL CEILING TILE PINNED INSULATION FABRIC PANEL PER GOLF SIMULATOR COMPOSITE METAL WALL PANEL SQUARE RECESSED DOWNLIGHT DECORATIVE SCONCE DECORATIVE CUSTOM CHANDELIER ROUND PENDANT LIGHT

LENSED LINEAR UTILITY STRIP CONCEALED LINEAR UNDERCABINET STRIP _____ TRACK / RAIL / LINEAR LED

> SURFACE MOUNT PANEL SMOKE DETECTOR

SURFACE-MOUNTED LIGHT BAR

COMBINATION SMOKE / CARBON MONOXIDE DETECTOR FIRE ALARM SPEAKER FIRE ALARM STROBE FIRE ALARM COMBINATION SPEAKER / STROBE

COMBINATION SMOKE / HEAT DETECTOR


EXIT SIGN SECURITY CAMERA WIRELESS ACCESS POINT AV SPEAKER

> MOTORIZED SINGLE ROLLER SHDAE - EQ-02.00 MOTORIZED DOUBLE ROLLER SHDAE - EQ-02.01 CEILING FAN - MECH EXHAUST

MECHANICAL LINEAR GRILLE CEILING ACCESS PANEL

CEILING CONTROL POINT **ELEVATION CHANGE**

Seattle, WA 98109 MEP Engineer
WSP USA 1001 Fourth Ave., Suite 3100 Seattle, WA 98154



• —

ASPEN GROUP

Aspen Group USA, LLC PO Box 980022

Park City, Utah 84098

Pool Consultant
Cloward H20

Provo, UT 84604

Midvale, Utah 84047

Specifications Writer
Friday Group

88 Mainelli Road

Middlebury, VT

Code Consultant Holmes

Seattle, WA 98104

600 1st Avenue, Suite 200A

Fire Protection Engineer

Jensen Hughes
One Research Drive, Suite 305C

Vertical Transportation Consulatant Lerch Bates

Structural Engineer
Magnusson Klemencic Associates

19515 North Creek Parkway, Suite 304

Westborough, MA 01581

Bothell, WA 98011

Seattle, WA 98101

Lighting Designer

1301 5th Ave, Suite 3200

1319 SE MLK Blvd, Suite 210 Portland, Oregon 97219

Building Envelope Consultant RDH

2101 N 34th St Seattle, WA 98103

Accessibility Consultant
Studio Pacifica

2144 Westlake Ave N, Suite F

2696 N University Ave, Suite 290

Landscape Architect

EPG Design
6949 South High Tech Drive, Suite 100

IFC SET 3 OF 3 05/31/2024

RCP - TOWER B - LVL 1 -AREA D

A6.1B.11d