ELECTRICAL CONNECTION SCHEDULE

EQUIPMENT TAG NUMBER	DESCRIPTION	LOCATION	INPUT FROM MECHANICAL AND PLUMBING SCHEDULES-DESIGN								BRANCH CIRCUIT		LOAD CALCULATION		SERVED FROM	EQUIPMENT CONNECTION BY		PART-B -INPUT FROM MECHANICAL AND PLUMBING SCHEDULES-FROM SUBMITTALS								
			QUANTITY	VOLTAGE	PHASE	HP	KW	FLA	MCA	MOCP	CONDUIT (SEE NOTE)	WIRE SIZE (AWG)	AMPS	KVA		E	M	BOD I SUBSTITUTE	VOLTAGE	PHASE	HP	KW	FLA	MCA	MOCP	EQUIPMENT CONNECTION TYPE
FCU-A-P2-1	SPLIT SYSTEM - FAN COIL (INDOOR UNIT)	ELEC SWITCHBOARD P214	1	208	1				3.20	15	1/2"	2 #12 & 1#12G	3.2	0.67	OUTDOOR UNIT	X										
FCU-A-P2-2	FAN COIL UNIT	RESTAURANT ELEC P264	1	208	1				3.20	15	1/2"	2 #12 & 1#12G	3.2	0.67	MP-P2A1	X										
FCU-A-1-1	SPLIT SYSTEM - FAN COIL (INDOOR UNIT)	FIRE COMMAND CENTER A124	1	208	1			2.2			1/2"	2 #12 & 1#12G	2.2	0.46	OUTDOOR UNIT	X										
FCU-A-1-2	FAN COIL UNIT	VESTIBULE A112	1	208	1				3.20	15	1/2"	2 #12 & 1#12G	3.2	0.67	LP-1A1	X										
FCU-A-6-1	SPLIT SYSTEM - FAN COIL (INDOOR UNIT)	ELEC A602	1	208	1			2.2			1/2"	2 #12 & 1#12G	2.2	0.46	OUTDOOR UNIT	X										
FCU-A-B1-1	SPLIT SYSTEM - FAN COIL (INDOOR UNIT)	STORAGE A001	1	208	1			3.2			1/2"	2 #12 & 1#12G	3.2	0.67	OUTDOOR UNIT	X										
FCU-B-B-1	SPLIT SYSTEM - FAN COIL (INDOOR UNIT)	FIRE PUMP ROOM B011	1	208	1			2.2			1/2"	2 #12 & 1#12G	2.2	0.46	OUTDOOR UNIT	X										
FCU-B-P2-1	SPLIT SYSTEM - FAN COIL (INDOOR UNIT)	ELEC EMERGENCY P266	1	208	1			2.2			1/2"	2 #12 & 1#12G	2.2	0.46	OUTDOOR UNIT	X										
FCU-B-P2-2	FAN COIL UNIT	POOL MECH P236	1	208	1				3.20	15	1/2"	2 #12 & 1#12G	3.2	0.67	LP-P2B1	X										
FCU-B-P2-3	FAN COIL UNIT	WATER ENTRY P239	1	208	1				3.20	15	1/2"	2 #12 & 1#12G	3.2	0.67	LP-P2B1	X										
FCU-B-P2-4	FAN COIL UNIT	POOL MECH P260	1	208	1				3.20	15	1/2"	2 #12 & 1#12G	3.2	0.67	LP-P2B1	X										
FCU-B-P1-1	SPLIT SYSTEM - FAN COIL (INDOOR UNIT)	ELECTRICAL P107	1	208	1			2.2			1/2"	2 #12 & 1#12G	2.2	0.46	OUTDOOR UNIT	X										
FCU-B-P1-2	SPLIT SYSTEM - FAN COIL (INDOOR UNIT)	ELECTRICAL P102	1	208	1			2.2		15	1/2"	2 #12 & 1#12G	2.2	0.46	OUTDOOR UNIT	X										
FCU-B-P1-3	FAN COIL UNIT	MECH P105	1	208	1			5.1			1/2"	2 #12 & 1#12G	5.1	1.06	MP-P1B1	X										
FCU-B-1-1	FAN COIL UNIT	VESTIBULE B120	1	208	1				3.20	15	1/2"	2 #12 & 1#12G	3.2	0.67	LP-1B1	X										
FCU-B-7-1	SPLIT SYSTEM - FAN COIL (INDOOR UNIT)	ELEC B706	1	208	1			2.2			1/2"	2 #12 & 1#12G	2.2	0.46	OUTDOOR UNIT	X										
FCU-C-P1-1	SPLIT SYSTEM - FAN COIL (INDOOR UNIT)	TOWER C EMERG ELEC RM C007	1	208	1			2.2			1/2"	2 #12 & 1#12G	2.2	0.46	OUTDOOR UNIT	X										
FCU-C-P1-2	FAN COIL UNIT	VESTIBULE C002	1	208	1				3.20		1/2"	2 #12 & 1#12G	3.2	0.67	LP-P1C1	X										
FCU-C-P1-3	FAN COIL UNIT	SWITCHGEAR C010	1	208	1				3.20	15	1/2"	2 #12 & 1#12G	3.2	0.67	LP-P1C1	X										
FCU-C-1-1	FAN COIL UNIT	MEP C106	1	208	1				5.10	15	1/2"	2 #12 & 1#12G	5.1	1.06	MP-1C1	X										
FCU-C-1-2	FAN COIL UNIT	GARAGE	1	208	1				3.20	15	1/2"	2 #12 & 1#12G	3.2	0.67	MP-1C1	X										
CU-A-P2-1	AIR COOLED CONDENSER	OUTDOOR	1	208	1				23.00		3/4"	2 #10 & 1#10G	23.0	4.78	ELP-P2B1	X										
CU-A-P2-2	AIR COOLED CONDENSER	OUTDOOR	1	208	1				10.00		1/2"	2 #12 & 1#12G	10.0	2.08	ELP-P2B1	X										
CU-A-P2-3	AIR COOLED CONDENSER	OUTDOOR	1	208	1				10.00		1/2"	2 #12 & 1#12G	10.0	2.08	ELP-P2B2	X										
CU-A-R-1	AIR COOLED CONDENSER	OUTDOOR	1	208	1				19.00		3/4"	2 #10 & 1#10G	19.0	3.95	ELP-1A1	X										
CU-B-P2-2	AIR COOLED CONDENSER	OUTDOOR	1	208	1				25.40		1"	2 #8 & 1#10G	25.4	5.28	ELP-P2B1	X										
CU-B-P2-1	AIR COOLED CONDENSER	OUTDOOR	1	208	1				10.00		1/2"	2 #12 & 1#12G	10.0	2.08	ELP-P2B1	X										
CU-B-P1-1	AIR COOLED CONDENSER	OUTDOOR	1	208	1				19.00		3/4"	2 #10 & 1#10G	19.0	3.95	ELP-P1B1	X										
CU-B-R-1	AIR COOLED CONDENSER	OUTDOOR	1	208	1				10.00		1/2"	2 #12 & 1#12G	10.0	2.08	ELP-P1B1	X										
CU-C-P1-1	AIR COOLED CONDENSER	OUTDOOR	1	208	1				10.00		1/2"	2 #12 & 1#12G	10.0	2.08	ELP-P1C1	X										
MUA-A-P2-1	KITCHEN MAKE-UP AIR UNIT	A - LEVEL P2	1	480	3	7 1/2					1/2"	3 #12 & 1#12G	11.0	9.15	LPH-P2A2	X										
PCU-A-B-1	KITCHEN POLLUTION CONTROL UNIT	A - LEVEL B	1	480	3	10		12.0			1/2"	3 #12 & 1#12G	14.0	11.64	LPH-P2A2	X										
UH-A-P2-1	UNIT HEATER - GAS	TOWER A GARAGE	1	480	3			14.4			1/2"	3 #12 & 1#12G	14.4	11.97	MPH-P2A1	X										
UH-B-P1-1	UNIT HEATER - GAS	TOWER B GARAGE	1	480	3			6.7			1/2"	3 #12 & 1#12G	6.7	5.57	MPH-P1B1	X										
UH-C-P1-1	UNIT HEATER - GAS	TOWER C GARAGE	1	120	1			17.6			3/4"	2 #10 & 1#10G	17.6	2.11	LP-P1C1	X										
UH-C-P1-2	UNIT HEATER - GAS	TOWER C GARAGE	1	120	1			17.6			3/4"	2 #10 & 1#10G	17.6	2.11	LP-P1C1	X										
UH-A	UNIT HEATER - ELECTRIC	STAIR	1	120	1		1.00				1/2"	2 #12 & 1#12G	8.3	1.00	VARIOUS	X										
PCHWP-A-B-1	PUMP	PRIMARY CHILLED WATER	1	480	3	10.00					1/2"	3 #12 & 1#12G	14.0	11.64	LPH-BA1	X										**VFD**
PCHWP-A-B-2	PUMP	PRIMARY CHILLED WATER	1	480	3	10.00					1/2"	3 #12 & 1#12G	14.0	11.64	LPH-BA1	X										**VFD**
PHWP-A-B-1	PUMP	PRIMARY HOT WATER	1	480	3	5.00					1/2"	3 #12 & 1#12G	7.6	6.32	LPH-BA1	X										**VFD**
PHWP-A-B-2	PUMP	PRIMARY HOT WATER	1	480	3	5.00					1/2"	3 #12 & 1#12G	7.6	6.32	LPH-BA1	X										**VFD**
SCHWP-A-B-1	PUMP	SECONDARY CHILLED WATER	1	480	3	5.00					1/2"	3 #12 & 1#12G	7.6	6.32	LPH-BA1	X										**VFD**
SCHWP-A-B-2	PUMP	SECONDARY CHILLED WATER	1	480	3	5.00					1/2"	3 #12 & 1#12G	7.6	6.32	LPH-BA1	X										**VFD**
SHWP-A-B-1	PUMP	SECONDARY HOT WATER	1	480	3	5.00					1/2"	3 #12 & 1#12G	7.6	6.32	LPH-BA1	X										**VFD**
SHWP-A-B-2	PUMP	SECONDARY HOT WATER	1	480	3	5.00					1/2"	3 #12 & 1#12G	7.6	6.32	LPH-BA1	X										**VFD**
BP-A-B-1	PUMP	BOILER 1	1	480	3	2					1/2"	3 #12 & 1#12G	3.4	2.83	LPH-BA1	X										**VFD**
BP-A-B-2	PUMP	BOILER 2	1	480	3	2					1/2"	3 #12 & 1#12G	3.4	2.83	LPH-BA1	X										**VFD**
BP-A-B-3	PUMP	BOILER 3	1	480	3	2					1/2"	3 #12 & 1#12G	3.4	2.83	LPH-BA1	X										**VFD**
PCHWP-B-P1-1	PUMP	PRIMARY CHILLED WATER	1	480	3	10.00					1/2"	3 #12 & 1#12G	14.0	11.64	MPH-P1B1	X										**VFD**
PCHWP-B-P1-2	PUMP	PRIMARY CHILLED WATER	1	480	3	10.00					1/2"	3 #12 & 1#12G	14.0	11.64	MPH-P1B1	X										**VFD**
PHWP-B-P1-1	PUMP	PRIMARY HOT WATER	1	480	3	5					1/2"	3 #12 & 1#12G	7.6	6.32	MPH-P1B1	X										**VFD**
PHWP-B-P1-2	PUMP	PRIMARY HOT WATER	1	480	3	5					1/2"	3 #12 & 1#12G	7.6	6.32	MPH-P1B1	X										**VFD**
SCHWP-B-P1-1	PUMP	SECONDARY CHILLED WATER	1	480	3	5					1/2"	3 #12 & 1#12G	7.6	6.32	MPH-P1B1	X										**VFD**
SCHWP-B-P1-2	PUMP	SECONDARY CHILLED WATER	1	480	3	5					1/2"	3 #12 & 1#12G	7.6	6.32	MPH-P1B1	X										**VFD**
SHWP-B-P1-1	PUMP	SECONDARY HOT WATER	1	480	3	5					1/2"	3 #12 & 1#12G	7.6	6.32	MPH-P1B1	X										**VFD**
SHWP-B-P1-2	PUMP	SECONDARY HOT WATER	1	480	3	5					1/2"	3 #12 & 1#12G	7.6	6.32	MPH-P1B1	X										**VFD**
BP-B-P1-1	PUMP	BOILER 1	1	480	3	2					1/2"	3 #12 & 1#12G	3.4	2.83	MPH-P1B1	X										**VFD**
BP-B-P1-2	PUMP	BOILER 2	1	480	3	2					1/2"	3 #12 & 1#12G	3.4	2.83	MPH-P1B1	X										**VFD**
BP-B-P1-3	PUMP	BOILER 3	1	480	3	2					1/2"	3 #12 & 1#12G	3.4	2.83	MPH-P1B1	X										**VFD**
SMBP-B-P1-1	PUMP	SNOWMELT	1	480	3	40					1-1/4"	3 #6 & 1#8G	52.0	43.23	MPH-P1B1	X										**VFD**
SMBP-B-P1-2	PUMP	SNOWMELT	1	480	3	40					1-1/4"	3 #6 & 1#8G	52.0	43.23	MPH-P1B1	X										**VFD**
SMBP-B-P1-3	PUMP	SNOWMELT	1	480	3	40					1-1/4"	3 #6 & 1#8G	52.0	43.23	MPH-P1B1	X										**VFD**
PCHWP-C-1-1	PUMP	PRIMARY CHILLED WATER	1	480	3	7.00					1/2"	3 #12 & 1#12G	7.6	6.32	MPH-1C1	X										**VFD**
PCHWP-C-1-2	PUMP	PRIMARY CHILLED WATER	1	480	3	7.00					1/2"	3 #12 & 1#12G	7.6	6.32	MPH-1C1	X										**VFD**
PHWP-C-1-1	PUMP	PRIMARY HOT WATER	1	480	3	5					1/2"	3 #12 & 1#12G	7.6	6.32	MPH-1C1	X										**VFD**
PHWP-C-1-2	PUMP	PRIMARY HOT WATER	1	480	3	5					1/2"	3 #12 & 1#12G	7.6	6.32	MPH-1C1	X										**VFD**
SCHWP-C-1-1	PUMP	SECONDARY CHILLED WATER	1	480	3	5					1/2"	3 #12 & 1#12G	7.6	6.32	MPH-1C1	X										**VFD**
SCHWP-C-1-2	PUMP	SECONDARY CHILLED WATER	1	480	3	5					1/2"	3 #12 & 1#12G	7.6	6.32	MPH-1C1	X										**VFD**
SHWP-C-1-1	PUMP	SECONDARY HOT WATER	1	480	3	5					1/2"	3 #12 & 1#12G	7.6	6.32	MPH-1C1	X										**VFD**
SHWP-C-1-2	PUMP	SECONDARY HOT WATER	1	480	3	5					1/2"	3 #12 & 1#12G	7.6	6.32	MPH-1C1	X										**VFD**
BP-C-1-1	PUMP	BOILER 1	1	480	3	2					1/2"	3 #12 & 1#12G	3.4	2.83	MPH-1C1	X										**VFD**
BP-C-1-2	PUMP	BOILER 2	1	480	3	2					1/2"	3 #12 & 1#12G	3.4	2.83	MPH-1C1	X										**VFD**
BP-C-1-3	PUMP	BOILER 3	1	480	3	2					1/2"	3 #12 & 1#12G	3.4	2.83	MPH-1C1	X										**VFD**
B-A-B-1	HOT WATER BOILER	TOWER A LEVEL B	1	120	1			7.0	9.0		1/2"	2 #12 & 1#12G	7.0	0.84	LP-BA1	X										
B-A-B-2	HOT WATER BOILER	TOWER A LEVEL B	1	120	1			7.0	9.0		1/2"	2 #12 & 1#12G	7.0	0.84	LP-BA1	X										
B-A-B-3	HOT WATER BOILER	TOWER A LEVEL B	1	120	1			7.0	9.0		1/2"	2 #12 & 1#12G	7.0	0.84	LP-BA1	X										
B-B-P1-1	HOT WATER BOILER	TOWER B LEVEL P1	1	120	1			6.0	8.00		1/2"	2 #12 & 1#12G	6.0	0.72	MP-P1B1	X										
B-B-P1-2	HOT WATER BOILER	TOWER B LEVEL P1	1	120	1			6.0	8.00		1/2"	2 #12 & 1#12G	6.0	0.72	MP-P1B1	X										
B-B-P1-3	HOT WATER BOILER	TOWER B LEVEL P1	1	120	1			6.0	8.00		1/2"	2 #12 & 1#12G	6.0	0.72	MP-P1B1	X										
B-B-P1-4	HOT WATER BOILER	TOWER B LEVEL P1	1	120	1			13.0	16.0		1/2"	2 #12 & 1#12G	13.0	1.56	MP-P1B1	X										
B-B-P1-5	HOT WATER BOILER	TOWER B LEVEL P1	1	120	1			13.0	16.0		1/2"	2 #12 & 1#12G	13.0	1.56	MP-P1B1	X										
B-B-P1-6	HOT WATER BOILER	TOWER B LEVEL P1	1	120	1			13.0	16.0		1/2"	2 #12 & 1#12G	13.0	1.56	MP-P1B1	X										
B-B-P1-7	HOT WATER BOILER	TOWER B LEVEL P1	1	120	1			13.0	16.0		1/2"	2 #12 & 1#12G	13.0	1.56	MP-P1B1	X										
B-B-P1-8	HOT WATER BOILER	TOWER B LEVEL P1	1	120	1			13.0	16.0		1/2"	2 #12 & 1#12G	13.0	1.56	MP-P1B1	X										
B-B-P1-9	HOT WATER BOILER	TOWER B LEVEL P1	1	120	1			13.0	16.0		1/2"	2 #12 & 1#12G	13.0	1.56	MP-P1B1	X										
B-C-1-1	HOT WATER BOILER	TOWER C LEVEL 1	1	120	1			13.0	16.0		1/2"	2 #12 & 1#12G	13.0	1.56	MP-1C1	X										
B-C-1-2	HOT WATER BOILER	TOWER C LEVEL 1	1	120	1			13.0	16.0		1/2"	2 #12 & 1#12G	13.0	1.56	MP-1C1	X										
B-C-1-3	HOT WATER BOILER	TOWER C LEVEL 1	1	120	1			13.0	16.0		1/2"	2 #12 & 1#12G	13.0	1.56	MP-1C1	X										
FPT-A-B1-1	FAN POWERED TERMINAL W/ HOT WATER COIL	GAME LOUNGE	1	277	1			5.3			1/2"	2 #12 & 1#12G	5.3	1.47	LPH-BA1	X										
FPT-A-B1-2	FAN POWERED TERMINAL W/ HOT WATER COIL	EMPLOYEE BREAK	1	277	1			1.3			1/2"	2 #12 & 1#12G	1.3	0.36	LPH-BA1	X										
FPT-A-B1-3	FAN POWERED TERMINAL W/ HOT WATER COIL	BOWLING LOUNGE	1	277	1			5.3			1/2"	2 #12 & 1#12G	5.3	1.47	LPH-BA1	X										
FPT-A-B1-4	FAN POWERED TERMINAL W/ HOT WATER COIL	BOWLING LANE	1	277	1			4.4			1/2"	2 #12 & 1#12G	4.4	1.22	LPH-BA1	X										
FPT-A-1-1	FAN POWERED TERMINAL W/ HOT WATER COIL	SPA LOUNGE	1	277	1			2.2			1/2"	2 #12 & 1#12G	2.2	0.61	MPH-1A1	X										
FPT-A-1-2	FAN POWERED TERMINAL W/ HOT WATER COIL	TREATMENT SINGLE	1	277	1			1.3			1/2"	2 #12 & 1#12G	1.3	0.36	MPH-1A1	X										
FPT-A-1-3	FAN POWERED TERMINAL W/ HOT WATER COIL	LOCKER ROOM A123	1	277	1			4.4			1/2"	2 #12 & 1#12G	4.4	1.22	MPH-1A1	X										
FPT-A-1-4	FAN POWERED TERMINAL W/ HOT WATER COIL	LOCKER ROOM A122	1	277	1			2.2			1/2"	2 #12 & 1#12G	2.2	0.61	MPH-1A1	X										
FPT-A-1-5	FAN POWERED TERMINAL W/ HOT WATER COIL	PRIVATE DINING	1	277	1			4.4			1/2"	2 #12 & 1#12G	4.4	1.22	MPH-1A1	X										
FPT-A-1-6	FAN POWERED TERMINAL W/ HOT WATER COIL	FITNESS	1	277	1			5.3			1/2"	2 #12 & 1#12G	5.3	1.47	MPH-1A1	X										
FPT-A-1-7	FAN POWERED TERMINAL W/ HOT WATER COIL	STRENGTH TRAINING	1	277	1			2.2			1/2"	2 #12 & 1#12G	2.2	0.61	MPH-1A1	X										
FPT-A-1-8	FAN POWERED TERMINAL W/ HOT WATER COIL	YOGA	1	277	1			2.2			1/2"	2 #12 & 1#12G	2.2	0.61	MPH-1A1	X										
FPT-A-1-9	FAN POWERED TERMINAL W/ HOT WATER COIL	TREATMENT DOUBLE	1	277	1			1.3			1/2"	2 #12 & 1#12G	1.3	0.36	MPH-1A1	X										
FPT-A-1-10	FAN POWERED TERMINAL W/ HOT WATER COIL	KITCHEN	1	277	1			5.3			1/2"	2 #12 & 1#12G	5.3	1.47	MPH-1A1	X										
FPT-B-1-1	FAN POWERED TERMINAL W/ HOT WATER COIL	GUEST BUSINESS CENTER	1	277	1			5.3			1/2"	2 #12 & 1#12G	5.3	1.47	MPH-1B1	X										
FPT-B-1-2	FAN POWERED TERMINAL W/ HOT WATER COIL	MANAGER OFFICE	1	277	1			5.3			1/2"	2 #12 & 1#12G	5.3	1.47	MPH-1B1	X										
FPT-B-1-3	FAN POWERED TERMINAL W/ HOT WATER COIL	SKI LOUNGE KITCHEN	1	277	1			2.2			1/2"	2 #12 & 1#12G	2.2	0.61	MPH-1B1	X										
FPT-B-1-4	FAN POWERED TERMINAL W/ HOT WATER COIL	SKI LOUNGE B108 W	1	277	1			5.3			1/2"	2 #12 & 1#12G	5.3	1.47	MPH-1B1	X										
FPT-B-1-5	FAN POWERED TERMINAL W/ HOT WATER COIL	SKI LOUNGE B108 NW	1	277	1			5.3			1/2"	2 #12 & 1#12G	5.3	1.47	MPH-1B1	X										
FPT-B-1-6	FAN POWERED TERMINAL W/ HOT WATER COIL	SKI LOUNGE B106 B107	1	277	1			5.3			1/2"	2 #12 & 1#12G	5.3	1.47	MPH-1B1	X										
FPT-B-1-7	FAN POWERED TERMINAL W/ HOT WATER COIL	SKI LOUNGE B108	1	277	1			2.2			1/2"	2 #12 & 1#12G	2.2	0.61	MPH-1B1	X										
FPT-B-1-8	FAN POWERED TERMINAL W/ HOT WATER COIL	KIDS ROOM	1	277	1			5.3			1/2"	2 #12 & 1#12G	5.3	1.47	MPH-1B1	X										
FPT-B-1-9	FAN POWERED TERMINAL W/ HOT WATER COIL	SKI VALET BOH	1	277	1			2.2			1/2"	2 #12 & 1#12G	2.2	0.61	MPH-1B1	X										
FPT-B-1-10	FAN POWERED TERMINAL W/ HOT WATER COIL	SKI VALET	1	277	1			5.3			1/2"	2 #12 & 1#12G	5.3	1.47	MPH-1B1	X										
FPT-B-1-11	FAN POWERED TERMINAL W/ HOT WATER COIL	SKI LOCKERS	1	277	1			1.3			1/2"	2 #12 & 1#12G	1.3	0.36	MPH-1B1	X										
FPT-B-1-12	FAN POWERED TERMINAL W/ HOT WATER COIL	SKI LOUNGE B107 E	1	277	1			5.3			1/2"	2 #12 & 1#12G	5.3	1.47	MPH-1B1	X										
FPT-B-1-13	FAN POWERED TERMINAL W/ HOT WATER COIL	BC CONNECTOR	1	277	1			5.3			1/2"	2 #12 & 1#12G	5.3	1.47	MPH-1B1	X										
FPT-C-1-1A	FAN POWERED TERMINAL W/ HOT WATER COIL	ENTRY LOBBY	1	277	1			2.2			1/2"	2 #12 & 1#12G	2.2	0.61	MPH-1C1	X										
FPT-C-1-1B	FAN POWERED TERMINAL W/ HOT WATER COIL	ENTRY LOBBY	1	277	1			2.2			1/2"	2 #12 & 1#12G	2.2	0.61	MPH-1C1	X										
FPT-C-1-2	FAN POWERED TERMINAL W/ HOT WATER COIL	SKIER LOUNGE	1	277	1			2.2			1/2"	2 #12 & 1#12G	2.2	0.61	MPH-1C1	X										
FPT-C-1-3	FAN POWERED TERMINAL W/ HOT WATER COIL	LOUNGE	1	277	1			2.2			1/2"	2 #12 & 1#12G	2.2	0.61	MPH-1C1	X										
FPT-C-1-4	FAN POWERED TERMINAL W/ HOT WATER COIL	GOLF SIMULATOR	1	277	1			1.3			1/2"	2 #12 & 1#12G	1.3	0.36	MPH-1C1	X										
FPT-C-1-5	FAN POWERED TERMINAL W/ HOT WATER COIL	GOLF SIMULATOR	1	277	1			2.2			1/2"	2 #12 & 1#12G	2.2	0.61	MPH-1C1	X										
FPT-C-1-6	FAN POWERED TERMINAL W/ HOT WATER COIL	HOUSEKEEPING	1	277	1			2.2			1/2"	2 #12 & 1#12G	2.2	0.61	MPH-1C1	X										
B-1	DOMESTIC HOT WATER HEATER	TOWER B WATER ENTRY ROOM P239	1	120	1			5.0			1/2"	2 #12 & 1#12G	5.0	0.60	LP-P2B1	X										
B-2	DOMESTIC HOT WATER HEATER	TOWER B WATER ENTRY ROOM P239	1	120	1			5.0			1/2"	2 #12 & 1#12G	5.0	0.60	LP-P2B1	X										
ESP-1	ELEVATOR SUMP PUMP	TOWER A, ELEVATOR S1	1	480	3	0.50					1/2"	3 #12 & 1#12G	1.1	0.91	LP-BA1	X										
ESP-2	ELEVATOR SUMP PUMP	TOWER A, ELEVATOR T1	1	480	3	0.50					1/2"	3 #12 & 1#12G	1.1	0.91	ELP-BA1	X										
ESP-3	ELEVATOR SUMP PUMP	TOWER A, ELEVATOR T2	1	480	3	0.50					1/2"	3 #12 & 1#12G	1.1	0.91	ELP-BA2	X										
ESP-4	ELEVATOR SUMP PUMP	TOWER B, ELEVATOR T3	1	480	3	0.50					1/2"	3 #12 & 1#12G	1.1	0.91	ELP-BB1	X										
ESP-5	ELEVATOR SUMP PUMP	TOWER B, ELEVATOR T4	1	480	3	0.50					1/2"	3 #12 & 1#12G	1.1	0.91	ELP-BB2	X										
ESP-6	ELEVATOR SUMP PUMP	TOWER B, ELEVATOR T5	1	480	3	0.50					1/2"	3 #12 & 1#12G	1.1	0.91	ELP-P1C1	X										
BP-1	BOOSTER PUMP	TOWER B WATER ENTRY ROOM P239	1	480	3	45.00					1-1/4"