

1 TOWER C - LEVEL 8 MECHANICAL PIPING PLAN


SCALE: 1/8" = 1'-0"

SHEET NOTES:

- A. ALL BRANCH PIPING SIZE OF CHILLED WATER AND HOT WATER TO FAN COIL UNIT IS 1" UNLESS OTHERWISE NOTED.
- B. ALL BRANCH PIPING SIZE OF HOT WATER TO FAN POWERED TERMINAL UNIT IS 1" UNLESS OTHERWISE NOTED.
- C. ROUTE 3/4" CONDENSATE FROM FPTS AND FCUS TO NEAREST SINK TAILPIECE PER DETAIL M5.06/8.

NUMBERED NOTES:

1 PROVIDE HEAT TRACE ON ALL EXPOSED PIPING. REFER TO ELECTRICAL DRAWINGS FOR 120/1 CONNECTION



Reserved for permit stamp

• —



Pool Consultant Cloward H20 2696 N University Ave, Suite 290 Provo, UT 84604
Landscape Architect EPG Design 6949 South High Tech Drive, Suite 100 Midvale, Utah 84047
Specifications Writer Friday Group 88 Mainelli Road Middlebury, VT
Code Consultant Holmes 600 1st Avenue, Suite 200A Seattle, WA 98104
Fire Protection Engineer Jensen Hughes One Research Drive, Suite 305C Westborough, MA 01581
Vertical Transportation Consulatant Lerch Bates 19515 North Creek Parkway, Suite 304 Bothell, WA 98011
Structural Engineer Magnusson Klemencic Associates 1301 5th Ave, Suite 3200 Seattle, WA 98101
<u>Lighting Designer</u> O- 1319 SE MLK Blvd, Suite 210 Portland, Oregon 97219
Building Envelope Consultant RDH 2101 N 34th St Seattle, WA 98103
Accessibility Consultant Studio Pacifica 2144 Westlake Ave N, Suite F Seattle, WA 98109

principal architect	t	
project manager		
drawn by	<i>'</i>	_
checked by	Checker	_
job no.		
date	05/31/2024	
revisions:		
-		
_		
D 08/23/2024 ASI	003	
		by

IFC Set 3 of 3 05/31/2024

TOWER C - LVL 8 MECHANICAL PIPING PLAN M3.2C.18