



- A. REFER TO M2.4 SERIES FOR ENLARGED PLANS.
- B. FIREPLACE FLUE ROUTING SHOWN FOR REFERENCE. REFER TO ENLARGED UNIT PLANS FOR ROUTING AND SIZING DETAIL.
- C. MECHANICAL EQUIPMENT SHOWN FOR REFERENCE. REFER TO ENLARGED UNIT PLANS FOR DETAIL.
- D. ALL DUCTS AND EQUIPMENT LOCATED IN THE GARAGE SHALL BE INSTALLED TIGHT TO UNDERSIDE OF THE SLAB TO MAINTAIN 8'-6" CLEARANCES FOR VEHICLES.

- 1 SEE ARCHITECTURAL DRAWINGS FOR INTAKE WELL INFORMATION.
- 2
- 3 ARCHITECT TO PROVIDE 58-SQ-FT PA GARAGE AND SPFF AIR INTAKE.
- 4 ROUTE CONDENSATE TO NEAREST FLOOR DRAIN.
- 5 GENERATOR REMOTE RADATOR. PROVIDE BACKDRIFT DAMPERS ON THE EXHAUST AIR DUCT.
- 6 EQUIPMENT SHALL BE MOUNTED ON A RAISED CONCRETE PLATFORM ABOVE GARAGE DRIVE LEVEL.
- 7 STAR STATION PRESSURIZATION FANS AND ASSOCIATED NETWORK TO BE LOCATED IN 3-4 INCH PATED ENCLOSURE ADJACENT TO FAN. SEE ARCHITECTURAL DRAWINGS FOR ENCLOSURE DETAIL.
- 8 REFER TO M&M FOR RUGS & HYDRONIC RISER DIAGRAM AND MECHANICAL ROOM PIPE CONFIGURATION.
- 9 1-CFM / SQFT PROVIDED FOR ELEVATOR LOBBY PRESSURIZATION.
- 10 PROVIDE ENERGY-SMDS-S MODULATING DAMPER OFF BOILER EXHAUST STACK WITH 120V/1PH ELECTRICAL POWER.
- 11 DISCHARGE AND/OR INTAKE - PROTECT OPENING WITH VMS.
- 12 PROVIDE MODULATING PRESSURE CONTROLLER WITH 120V/1PH ELECTRICAL POWER.
- 13 FUTURE BOILER FOR RADIANT HYDRONIC SNOWMELT SYSTEM TO BE DESIGN BUILT BY OTHERS



Olson Kundig

SOMMET BLANC
9300 Marsac Ave (B2 East Parcel)
Park City, Utah 84060



Pool Consultant
Cloward H20
2696 N University Ave, Suite 290
Provo, UT 84604

Landscape Architect
EPG Design
8949 South High Tech Drive, Suite 100
Midvale, Utah 84047

Specifications Writer
Friday Group
88 Mainelli Road
Middlebury, VT

Code Consultant
Holmes
800 1st Avenue, Suite 200A
Seattle, WA 98104

Fire Protection Engineer
Jensen Hughes
One Research Drive, Suite 305C
Westborough, MA 01581

Vertical Transportation Consultant
Lerch Bates
19515 North Creek Parkway, Suite 304
Bothell, WA 98011

Structural Engineer
Magnusson Klemencic Associates
1301 5th Ave, Suite 3200
Seattle, WA 98101

Lighting Designer
O.
1319 SE MLK Blvd, Suite 210
Portland, Oregon 97219

Building Envelope Consultant
RDH
2101 N 34th St
Seattle, WA 98103

Accessibility Consultant
Studio Pacifica
2144 Westlake Ave N, Suite F
Seattle, WA 98109

MEP Engineer
WSP USA
1001 Fourth Ave., Suite 3100
Seattle, WA 98154

principal architect _____
project manager _____
drawn by _____
checked by Checker _____
job no. _____
date 5/31/2024

revisions:

J 01/10/2025 ASI 6

no.	date	by
-----	------	----

IFC Set 3 of 3
5/31/2024

TOWER B - LVL P1
MECHANICAL DUCT
PLAN

M2.2B.03