


A. CONFIRM EXACT LOCATION OF ALL WALL DEVICES WITH ARCHITECTURAL ELEVATIONS.  
B. CONFIRM ALL CEILING AND WALL ACCESS DOORS WITH ARCHITECTURAL, RCP'S AND WALL ELEVATIONS.  
C. REFER TO M3-24-01 THROUGH M3-2C-R FOR RADIANT FLOOR HWS/R PIPING ROUTING AND SIZING.  
D. PROVIDE 1-INCH ACUSTIC LINING FOR ENTIRITY OF MAIN DUCT RUN OFF FAN COIL.  
E. ALL RESIDENTIAL TOILET EXHAUST, DRYER EXHAUST, AND KITCHEN RANGE HOOD EXHAUST TO BE PART OF A SUB-DUCT EXHAUST SYSTEM.  
F. ROUTE 3/4" CONDENSATE DRAINS FROM FCUS TO NEAREST SINK TAILPIPE.

1 50" CONCENTRIC FLUE TO GAS FIREPLACE. PROVIDE ORTAL IN-LINE 180 POWERVENT (120V/15A).  
2 RANGE HOOD EXHAUST FAN TO BE INTEGRAL WITH RANGE SPECIFIED BY THE ARCHITECT. INTERLOCK CONTROL WITH MUA-A.  
3 ELECTRICAL RADIANT FLOOR TO BE PROVIDED IN MASTER BATHROOM. SEE ELECTRICAL DRAWINGS.  
4 2" RETURN AIR SLOT  
5 OWNER OPTION: PROVIDE 208/16A/1 CONNECTION FOR APRILAIRE 800 HUMIDIFIER DOWNSTREAM OF FAN COIL UNIT. REFER TO ELECTRICAL DRAWINGS FOR DETAIL. REFER TO PLUMBING DRAWINGS FOR 1/2" CW CONNECTION. ROUTE 3/4" CD TO NEAREST SINK TAILPIECE. REFER TO DETAIL S.M.F.04.8 & S.M.F.04.12 FOR INSTANT LATION CONNECTION.


63	125	250	500	1000	2000	4000	8000
0	4	6	8	7	9	8	0

63	125	250	500	1000	2000	4000	8000
0	4	6	8	7	9	8	1



1 POWER PLANT  
SCALE: 1/4" = 1'-0"

project:  
**SOMMET BLANC**  
9300 Marsac Ave (B2 East Parcel)  
Crest, Cal. 94024



**Landscape Architect**  
**EPG Design**  
6949 South High Tech Drive, Suite 100  
Midvale, Utah 84047

Code Consultant  
**Holmes**  
600 1st Avenue, Suite 200A  
Seattle, WA 98104

**Vertical Transportation Consultants**  
**Lerch Bates**  
19515 North Creek Parkway, Suite  
200, Atlanta, GA 30329

Lighting Designer  
O-  
1319 SE MLK Blvd, Suite 210

**Accessibility Consultant**  
**Studio Pacifica**  
2144 Westlake Ave N, Suite F

Seattle, WA 98104

revisions:

no.	date	b
-----	------	---

M2.4.F