

SYMBOL	MANUFACTURER/MODEL/DESCRIPTION
	RAIN BIRD RWS-8-C-P W/RWS-SC00 1401 MINI PORT WATERING SYSTEM WITH 4" DIAMETER X 18" LONG WITH LOCKING GATE, SEMI-RIGID MESH TUBE AND RAIN BIRD 1401 1.25 GPM BUBBLER AS INDICATED WITH CHECK VALVE, PURPLE GATE AND SAND SCOOP FOR SANDY SOIL.
SYMBOL	MANUFACTURER/MODEL/DESCRIPTION
	REMOTE CONTROL DRIP VALVE RAINBIRD 100V APT W/ 30PSI PRESSURE REGULATOR AND 30 MESH WYE 3 STRAINER
	PVC TO POLY TUBING PIPE TRANSITION POINT FROM PVC LATERAL TO DRIP TUBING
	AREA TO RECEIVE DRIP LINE RAIN BIRD X-FCV-06-18
	XFCV ON SURFACE LANDSCAPE DRIP LINE WITH A HEAVY-DUTY 3.5 PSI PRESSURE VALVE, 0.8 GPM EMITTERS AT 18" O.C. DRIP LINE LATERALS ARE SPACED AT 18" APART, WITH EMITTERS OFFSET FOR TRIANGULAR PATTERN, GREAT FOR ELEVATION CHANGE, SPECIFY XF INSERT FITTINGS.
SYMBOL	MANUFACTURER/MODEL/DESCRIPTION
	RAIN BIRD PESS-PRS-D 1" PLASTIC INDUSTRIAL VALVES, LOW FLOW OPERATING CAPABILITY, GLOBE CONFIGURATION WITH PRESSURE-REGULATING MODULE, AND SCRUBBER TECHNOLOGY FOR RELIABLE PERFORMANCE IN DIRTY WATER IRRIGATION APPLICATIONS.
	LEMCO STAINLESS STEEL GATE VALVE LGT SIZE PER LINE SS, CLASS 125 304 STAINLESS STEEL.
	ZURN WILKINS 37XLB 3/4" REDUCED PRESSURE PRINCIPLE ASSEMBLY, SIZE PER PLAN SEE ARCHITECTURE MECHANICAL PLANS FOR FINAL LOCATION AND DETAILS.
	ZURN WILKINS 37XLB 3/4" REDUCED PRESSURE PRINCIPLE ASSEMBLY, SIZE PER PLAN SEE ARCHITECTURE MECHANICAL PLANS FOR FINAL LOCATION AND DETAILS.
	ZURN WILKINS 37XLB 3/4" REDUCED PRESSURE PRINCIPLE ASSEMBLY, SIZE PER PLAN SEE ARCHITECTURE MECHANICAL PLANS FOR FINAL LOCATION AND DETAILS.
	ZURN WILKINS 37XLB 3/4" REDUCED PRESSURE PRINCIPLE ASSEMBLY, SIZE PER PLAN SEE ARCHITECTURE MECHANICAL PLANS FOR FINAL LOCATION AND DETAILS.
	ZURN WILKINS 37XLB 3/4" REDUCED PRESSURE PRINCIPLE ASSEMBLY, SIZE PER PLAN SEE ARCHITECTURE MECHANICAL PLANS FOR FINAL LOCATION AND DETAILS.
	ZURN WILKINS 37XLB 3/4" REDUCED PRESSURE PRINCIPLE ASSEMBLY, SIZE PER PLAN SEE ARCHITECTURE MECHANICAL PLANS FOR FINAL LOCATION AND DETAILS.
	ZURN WILKINS 37XLB 3/4" REDUCED PRESSURE PRINCIPLE ASSEMBLY, SIZE PER PLAN SEE ARCHITECTURE MECHANICAL PLANS FOR FINAL LOCATION AND DETAILS.
	ZURN WILKINS 37XLB 3/4" REDUCED PRESSURE PRINCIPLE ASSEMBLY, SIZE PER PLAN SEE ARCHITECTURE MECHANICAL PLANS FOR FINAL LOCATION AND DETAILS.
	ZURN WILKINS 37XLB 3/4" REDUCED PRESSURE PRINCIPLE ASSEMBLY, SIZE PER PLAN SEE ARCHITECTURE MECHANICAL PLANS FOR FINAL LOCATION AND DETAILS.
	ZURN WILKINS 37XLB 3/4" REDUCED PRESSURE PRINCIPLE ASSEMBLY, SIZE PER PLAN SEE ARCHITECTURE MECHANICAL PLANS FOR FINAL LOCATION AND DETAILS.
	HYDRO POINT WEATHER TRACK LC 18 STATION 2WIRE INSTALL CONTROLLER IN UTILITY ROOM SEE ARCHITECTURE PLANS FOR LOCATION
	POINT OF CONNECTION 3" BUILDING A - FLOOR 8 - SEE PLUMBING PLANS FOR POINT OF CONNECTION AND BACKFLOW PREVENTER
	POINT OF CONNECTION 3" BUILDING B - FLOOR 3 - SEE PLUMBING PLANS
	POINT OF CONNECTION 3" BUILDING C - FLOOR 8 - SEE PLUMBING PLANS
	POINT OF CONNECTION 3" BUILDING A - FLOOR 4 - SEE PLUMBING PLANS
	POINT OF CONNECTION 3" BUILDING B - FLOOR 8 - SEE PLUMBING PLANS
	POINT OF CONNECTION 3" BUILDING A - FLOOR 8 - SEE PLUMBING PLANS
	POINT OF CONNECTION 3" BUILDING B - FLOOR 9 - SEE PLUMBING PLANS
	POINT OF CONNECTION 3" BUILDING C - FLOOR 9 - SEE PLUMBING PLANS
	IRRIGATION LATERAL LINE: PVC SCHEDULE 40

Generated:	2022-11-21 14:38
P.O.C. NUMBER: 02	Water Source Information:
Flow Available	BUILDING A - FLOOR 5 - SEE PLUMBING PLANS FOR POINT OF CONNECTION AND BACKFLOW PREVENTER
Point of Connection Size:	3/4"
Flow Available	13.31 GPM
PRESSURE AVAILABLE	
Static Pressure at POC:	60 PSI
Pressure Available:	60 PSI
DESIGN ANALYSIS	
Maximum Station Flow:	3.45 GPM
Flow Available at POC:	13.31 GPM
Residual Flow Available:	9.86 GPM
Critical Station:	14
Design Pressure:	30 PSI
Friction Loss:	0.04 PSI
Fittings Loss:	0 PSI
Elevation Loss:	0 PSI
Loss Through Valve:	1 PSI
Pressure Req. at Critical Station:	31.0 PSI
Loss for Fittings:	0.0 PSI
Loss for Main Line:	0.0 PSI
Loss for POC to Valve Elevation:	0 PSI
Loss for Backflow:	14 PSI
Critical Station Pressure at POC:	45.0 PSI
Pressure Available:	60 PSI
Residual Pressure Available:	15.0 PSI

Generated:	2022-11-21 14:40
P.O.C. NUMBER: 03	
Water Source Information:	LOBBY BUILDING - SEE PLUMBING PLANS FOR POC AND BACKFLOW PREVENTER
FLOW AVAILABLE	
Point of Connection Size:	3/4"
Flow Available:	13.31 GPM
PRESSURE AVAILABLE	
Static Pressure at POC:	60 PSI
Pressure Available:	60 PSI
DESIGN ANALYSIS	
Maximum Station Flow:	6.1 GPM
Flow Available at POC:	13.31 GPM
Residual Flow Available:	5.21 GPM
Critical Station:	15
Design Pressure:	20 PSI
Friction Loss:	0.25 PSI
Fittings Loss:	0.02 PSI
Elevation Loss:	0 PSI
Loss through Valve:	13.4 PSI
Pressure Req. at Critical Station:	33.7 PSI
Loss for Fittings:	0.06 PSI
Loss for Main Line:	0.62 PSI
Loss for POC to Valve Elevation:	14 PSI
Loss for Backflow:	14 PSI
Critical Station Pressure at POC:	48.4 PSI
Pressure Available:	60 PSI
Residual Pressure Available:	1.1 PSI

Generated:	2022-11-21 14:43
P.O.C. NUMBER: 04	
Water Source Information:	BUILDING B - FLOOR 3 - SEE PLUMBING PLANS
FLOW AVAILABLE	0.0 PSI
Point of Connection Size:	3/4"
Flow Available:	13.31 GPM
PRESSURE AVAILABLE	
Static Pressure at POC:	0 PSI
Pressure Available:	0 PSI
DESIGN ANALYSIS	
Maximum Station Flow:	1.45 GPM
Flow Available at POC:	13.31 GPM
Residual Flow Available:	11.86 GPM
Critical Station:	4
Design Pressure:	20 PSI
Friction Loss:	0.02 PSI
Fittings Loss:	0 PSI
Elevation Loss:	0 PSI
Loss through Valve:	6.25 PSI
Pressure Req. at Critical Station:	26.6 PSI
Loss for Fittings:	0 PSI
Loss for Main Line:	0.03 PSI
Loss for POC to Valve Elavation:	14 PSI
Loss for Backflow:	4.0 PSI
Critical Station Pressure at POC:	-40.6 PSI
Pressure Available:	0 PSI
Residual Pressure Available:	-40.6 PSI

Generated:	2022-11-21 14:43
P.O. NUMBER 05	BUILDING C - FLOOR 8 - SEE PLUMBING PLANS
Water/Wastewater Source Information:	
FLOW AVAILABLE	
Point of Connection Size:	3/4"
Flow Available	13.31 GPM
PRESSURE AVAILABLE	
Static Pressure at POC:	90 PSI
Pressure Available	90 PSI
DESIGN ANALYSIS	
Maximum Station Flow:	5.26 GPM
Flow Available at POC:	13.31 GPM
Residual Flow Available:	8.05 GPM
Critical Station:	6
Design Pressure:	20 PSI
Friction Loss:	1.33 PSI
Fittings Loss:	0.14 PSI
Elevation Loss:	14.4 PSI
Loss through Valve:	0.49 PSI
Pressure Req. at Critical Station:	35.9 PSI
Loss for Fittings:	0.06 PSI
Loss for Main Line:	0.36 PSI
Loss for POC to Valve Elevation:	0.90 PSI
Loss for Backflow:	0.06 PSI
Critical Station Pressure at POC:	49.3 PSI
Pressure Available:	90 PSI
Residual Pressure Available:	40.7 PSI

<p> P.O.C. Number: 08 Water Source Information: LOW AVAILABLE Point of Connection Size: 1/2" Available PRESSURE AVAILABLE Static Pressure at POC: Pressure Available DESIGN ANALYSIS Maximum Station Flow: Flow Available at POC: Residual Flow Available: Critical Station: Design Pressure: Friction Loss: Fittings Loss: Elevation Loss: Loss through Valve: Pressure Req. at Critical Station: Loss for Fittings: Loss for Main Line: Loss for POC to Valve Elevation: Loss for Backflow: Critical Station Pressure at POC: Pressure Available: Residual Pressure Available: </p>	<p> 2022-11-21 14:46 BUILDING A - FLOOR 6 - SEE PLUMBING PLANS 3/4" 13.31 GPM 90 PSI 90 PSI 10.08 GPM 13.21 GPM 3.23 GPM 8 PSI 20 PSI 1.54 PSI 0.16 PSI 0 PSI 13.4 PSI 35.1 PSI 0.02 PSI 0.34 PSI 0.34 PSI 14 PSI 49.5 PSI 49.5 PSI 40.2 PSI </p>
--	---

Generated:	2022-11-21 14:47
P.O.C. NUMBER: 07	
Water Source Information:	BUILDING B - FLOOR 8 - SEE PLUMBING PLANS
Flow Available	
Point of Connection Size:	3/4"
Flow Available	13.31 GPM
PRESSURE AVAILABLE	
Static Pressure at POC:	90 PSI
Pressure Available	90 PSI
DESIGN ANALYSIS	
Maximum Station Flow:	4.07 GPM
Flow Available at POC:	13.31 GPM
Residual Flow Available:	8.24 GPM
Critical Station:	10
Design Pressure:	20 PSI
Friction Loss:	0.44 PSI
Fittings Loss:	0.00 PSI
Elevation Loss:	0.00 PSI
Loss through Valve:	0.00 PSI
Pressure Req. at Critical Station:	31.4 PSI
Loss for Fittings:	0.02 PSI
Loss for Main Line:	0.29 PSI
Loss for POC to Valve Elevation:	0.00 PSI
Loss for Backflow:	14 PSI
Critical Station Pressure at POC:	45.7 PSI
Pressure Available:	90 PSI
Residual Pressure Available:	45.7 PSI

Generated:	2022-11-21 14:49
P.O.C. NUMBER: 08	
Water Source Information:	BUILDING A - FLOOR 8 - SEE PLUMBING PLANS
FLOW AVAILABLE	
Point of Connection Size:	3/4"
Flow Available	13.31 GPM
PRESSURE AVAILABLE	
Static Pressure at POC:	60 PSI
Pressure Available	90 PSI
DESIGN ANALYSIS	
Maximum Station Flow:	7.75 GPM
Flow Available at POC:	13.31 GPM
Residual Flow Available	5.56 GPM
Critical Station:	11
Design Pressure:	120 PSI
Friction Loss:	0.48 PSI
Fittings Loss:	0.04 PSI
Elevation Loss:	0.00 PSI
Loss through Valve:	13.34 PSI
Pressure Req. at Critical Station:	33.9 PSI
Loss for Fittings:	0.09 PSI
Loss for Main Line:	0.98 PSI
Loss for POC to Valve Elevation:	0.00 PSI
Loss for Backflow:	13.46 PSI
Critical Station Pressure at POC:	95.0 PSI
Pressure Available:	90 PSI
Residual Pressure Available:	40.5 PSI

Generated:	2022-11-21 14:51
C.O.C. NUMBER: 09	
Water Source Information:	BUILDING B - FLOOR 9 - SEE PLUMBING PLAN
LOW AVAILABLE	0.12 GPM
Point of Connection Size:	3/4"
LOW Available	13.31 GPM
PRESSURE AVAILABLE	
Static Pressure at POC:	90 PSI
Pressure Available	90 PSI
DESIGN ANALYSIS	
Maximum Station Flow:	7.86 GPM
Low Loss at POC:	13.31 GPM
Residual Flow Available:	5.33 GPM
Critical Station:	18
Design Pressure:	20 PSI
Friction Loss:	3.08 PSI
Fittings Loss:	0.31 PSI
Elevation Loss:	0 PSI
Loss from Valve:	15.4 PSI
Pressure Req. at Critical Station:	6.8 PSI
Loss for Fittings:	0.12 PSI
Loss for Main Line:	1.2 PSI
Loss for POC to Valve Elevation:	0 PSI
Loss for Backflow:	14.6 PSI
Critical Station Pressure at POC:	52.7 PSI
Pressure Available:	52.7 PSI
Residual Pressure Available:	37.5 PSI

generated:	2022-11-21 14:52
O.C. NUMBER: 10	
Water Source information:	BUILDING C - FLOOR 9 - SEE PLUMBING PLANS
LOW AVAILABLE	
oint of Connection Size:	3/4"
low Available:	13.31 GPM
RESSURE AVAILABLE	
table Pressure at POC:	90 PSI
ressure Available:	90 PSI
DESIGN ANALYSIS	
Maximum Station Flow:	13.31 GPM
low Available at POC:	13.31 GPM
esidual Flow Available:	7.68 GPM
ritical Station:	13
Design Pressure:	20 PSI
Friction Loss:	0.14 PSI
Fittings Loss:	0.01 PSI
Elevation Loss:	0 PSI
Loss Loss through Valve:	13.31 PSI
ressure Req. at Critical Station:	33.8 PSI
Loss Loss through Fittings:	0.03 PSI
Loss for Main Line:	0.3 PSI
Loss for POC to Valve Elevation:	0.03 PSI
Loss for Backflow:	1.4 PSI
ritical Station Pressure at POC:	48.0 PSI
ressure Available:	90 PSI
esidual Pressure Available:	42.0 PSI

1. THE IRRIGATION CONTRACTOR SHALL BE RESPONSIBLE THOROUGHLY FAMILIAR WITH THE SPECIFICATIONS FOR THIS AND RELATED WORK PRIOR TO CONSTRUCTION.
2. INSTALL POP-UP TYPE SPRINKLER HEADS INSTALLED IN LAWN AREAS SO THAT TOP OF SPRINKLER HEAD IS FLUSH WITH ADJACENT SIDEWALK OR CURB.
3. SET SPRINKLER HEADS PERPENDICULAR TO FINISH GRADE OF AREA TO BE IRRIGATED UNLESS OTHERWISE INDICATED ON DRAWINGS.
4. WHEN VERTICAL OBSTRUCTIONS (FIRE HYDRANTS, TREES, LIGHTS, ETC.) INTERFERE WITH SPRAY PATTERN OF SPRINKLER HEAD, CONTRACTOR IS TO PROVIDE PROPER COVERAGE, ADJUST SPRINKLER SYSTEM BY INSTALLING A QUARTER CIRCLE, HALF CIRCLE, OR ADJUSTABLE CIRCLE SPRINKLER HEAD ON EACH SIDE OF OBSTRUCTION SO AS TO PROVIDE PROPER COVERAGE. CONTRACTOR TO NOTIFY OWNER'S REPRESENTATIVE PRIOR TO MAKING ANY ADJUSTMENTS.
5. SPRINKLER SYSTEM DESIGN IS BASED ON MINIMUM OPERATING PRESSURE AND MAXIMUM FLOW DEMAND SHOWN ON IRRIGATION DRAWINGS AT EACH POINT-OF-CONNECTION. VERIFY WATER PRESSURE PRIOR TO CONSTRUCTION. REPORT DIFFERENCES BETWEEN WATER PRESSURE INDICATED ON DRAWINGS AND ACTUAL PRESSURE READING AT EACH POINT-OF-CONNECTION TO OWNER'S AUTHORIZED REPRESENTATIVE. EIGHT (8) P.S.I. PRESSURE DIFFERENCES ARE NOT REPORTED PRIOR TO START OF CONSTRUCTION, CONTRACTOR ASSUMES FULL RESPONSIBILITY FOR REVISIONS.
6. 120 VOLT ELECTRICAL POWER OUTLET AT THE CONTROLLER WILL BE PROVIDED BY GENERAL CONTRACTOR. MAKE FINAL HOOK-UP FROM ELECTRICAL OUTLET TO AUTOMATIC CONTROLLER. ALL WORK TO BE COMPLETED IN ACCORDANCE WITH CURRENT E.C.C.C. CODES.
7. THIS DESIGN IS DIAGRAMMATIC. PIPING, VALVES, ETC., MAY BE SHOWN WITH PAVED AREAS FOR DESIGN CLARIFICATION ONLY AND SHALL BE INSTALLED IN PLANTING AREAS WHERE POSSIBLE AVOID CONFLICTS BETWEEN SPRINKLER SYSTEM, PLANTING AND ARCHITECTURAL FEATURES. NO VALVE BOXES SHALL BE PLACED WITHIN TURF AREAS.
8. FLUSH AND ADJUST SPRINKLER HEADS FOR OPTIMUM PERFORMANCE AND TO PREVENT OVER SPRAY INTO ROADWAYS AND BUILDINGS. THIS INCLUDES SELECTING THE BEST GRADE OF ARC TO FIT SITE CONDITIONS AND TO THROTTLE FLOW CONTROL AT EACH VALVE TO OBTAIN OPTIMUM PRESSURE FOR EACH SYSTEM.
9. DO NOT WILLFULLY INSTALL SPRINKLER SYSTEM AS INDICATED ON DRAWINGS WHEN IT IS OBVIOUS IN FIELD THAT OBSTRUCTIONS, GRADE DIFFERENCES IN AREA DIMENSIONS EXIST THAT MIGHT NOT HAVE BEEN CONSIDERED DURING DESIGN. BRING SUCH OBSTRUCTIONS OR DIFFERENCES TO THE ATTENTION OF OWNER'S AUTHORIZED REPRESENTATIVE. IN EVENT THIS NOTIFICATION IS NOT PERFORMED, CONTRACTOR ASSUMES FULL RESPONSIBILITY FOR REVISIONS.
10. INSTALL PIPE MATERIALS AND EQUIPMENT AS SHOWN IN DETAILS. USE TEFLON TAPE ON PVC MALE PIPE THREADS ON SPRINKLER SWING JOINT AND VALVE ASSEMBLIES.
11. IT IS THE CONTRACTOR'S RESPONSIBILITY TO BECOME FAMILIAR WITH GRADE DIFFERENCES, LOCATION OF WALL, RETAINING WALLS, ETC. COORDINATE WORK WITH GENERAL CONTRACTOR AND OTHER SUB- CONTRACTORS FOR LOCATION AND INSTALLATION OF PIPE SLEEVES THROUGH WALLS, UNDER ROADWAYS, PAVING, STRUCTURES, ETC.
12. IN ADDITION TO SLEEVES SHOWN ON THE DRAWINGS, CONTRACTOR IS RESPONSIBLE FOR THE INSTALLATION OF PIPE SLEEVING AT ALL HARDCAPE CROSSINGS AND SEPARATE CONTROL WIRE SLEEVES OF SUFFICIENT SIZE UNDER PAVED AREAS.
13. THE FOLLOWING SHOULD BE NOTED REGARDING PIPE SIZING: IF A SECTION OF UNSIZED LATERAL IS LOCATED BETWEEN TWO IDENTICALLY SIZED SECTIONS THE UNSIZED SECTION SHALL BE OF THE SAME SIZE. IN NO CASE SHALL A SECTION OF PIPE BE SMALLER THAN ANY DOWNSTREAM SECTION LOCATED ON THE SAME LATERAL RUN.
14. THE IRRIGATION CONTRACTOR SHALL TURN OVER TO THE OWNER, TWO EACH OF ALL OPERATING KEYS AND SERVICING TOOLS NEEDED FOR COMPLETE ACCESS, ADJUSTMENT, AND REPAIR OF ALL IRRIGATION SYSTEM COMPONENTS. THIS INCLUDES SPECIALIZED TOOLS REQUIRED FOR COMPLETE DISASSEMBLY OF EACH SPRINKLER AND VALVE.
15. IRRIGATION SYSTEM IS DESIGNED FOR NON-POTABLE WATER USAGE. CONTRACTOR TO PROVIDE PURPLE CAPS FOR SPRAYS/ROTORS, AND BRAND "NON POTABLE" ON ALL VALVE BOXES IN 3-INCH HIGH LETTERS.

1. INSTALL EMITTERS ON UPHILL SIDE OF TREE OR SHRUB IF LOCATED ON A SLOPE.
2. VERIFICATION OF PLANT MATERIAL NAMES AND NUMBER OF EMITTERS PER VALVE STATION IS THE RESPONSIBILITY OF THE CONTRACTOR.
 - DRIP IRRIGATION LINES ARE SHOWN DIAGRAMMATIC FOR CLARITY. INSTALL ALL PIPING IN LANDSCAPE PLANTING AREAS.
3. INSTALL POLYETHYLENE DRIP LATERAL WITHIN PVC SLEEVE WHEN ROUTING UNDER PAVED SURFACES OR THROUGH PLANTER'S WALLS.
4. REFER TO PLANTING LEGEND FOR PLANT MATERIAL NAMES, ABBREVIATIONS, SPECIFIC SIZES, ON-CENTER SPACING AND ADDITIONAL INFORMATION.
5. PROVIDE ONE (1) FLUSH-VALVE ASSEMBLY AT EACH END OF DRIP ZONE LATERAL LATERAL OR AS SHOWN ON PLANS. LOCATE FLUSH-VALVE ASSEMBLY BOXES ADJACENT TO PLANTING BORDERS OR PAVING EDGES FOR MAINTENANCE CONVENIENCE.
6. THE MAXIMUM ALLOWABLE LENGTH DOWNSTREAM OF EACH ZONE CONTROL VALVE FOR THE 3/4" NOMINAL DIAMETER POLYETHYLENE DRIP LATERAL IS 250 FEET. FLOW MUST NOT EXCEED 0.5 GPM IF THE LENGTH OF FLOW EXCEEDS THE ALLOWABLE AMOUNT AN ADDITIONAL CONNECTION TO A PVC LATERAL WILL BE NECESSARY. IN NO CASE SHALL THE ACTUAL FLOW OF THE DRIP LATERAL BE INCREASED BY MORE THAN SIX THROUGH THE ADDITION OF MORE EMITTERS OR OTHER DEVICES TO THE END OF THE LATERAL.

NUMBER	MODEL	SIZE	TYPE	QPM	PSI	PSI @ POC
2	REMOTE CONTROL DRIP VALVE	3/4"	AREA FOR DRIPLINE	7.76	45.1	59.4
3	REMOTE CONTROL DRIP VALVE	3/4"	AREA FOR DRIPLINE	1.61	67.7	62.2
4	REMOTE CONTROL DRIP VALVE	3/4"	AREA FOR DRIPLINE	3.81	39.8	54.5
5	RAIN BIRO PESS-PRSS-D	1"	BUBBLER	1	31.0	
6	REMOTE CONTROL DRIP VALVE	3/4"	AREA FOR DRIPLINE	1.83	54.7	59.9
7	RAIN BIRO PESS-PRSS-D	1"	BUBBLER	0.5	31.4	
8	REMOTE CONTROL DRIP VALVE	3/4"	AREA FOR DRIPLINE	22.06	49.1	
9	REMOTE CONTROL DRIP VALVE	3/4"	AREA FOR DRIPLINE	1.61	67.7	59.7
10	REMOTE CONTROL DRIP VALVE	3/4"	AREA FOR DRIPLINE	1.3	45.5	59.8
11	REMOTE CONTROL DRIP VALVE	3/4"	AREA FOR DRIPLINE	26.76	43.6	65.0
12	REMOTE CONTROL DRIP VALVE	3/4"	AREA FOR DRIPLINE	1.61	67.7	62.2
13	REMOTE CONTROL DRIP VALVE	3/4"	AREA FOR DRIPLINE	12.67	43.3	65.0
14	RAIN BIRO PESS-PRSS-D	1"	BUBBLER	0.5	31.0	
15	REMOTE CONTROL DRIP VALVE	3/4"	AREA FOR DRIPLINE	1.62	67.7	57.2
16	REMOTE CONTROL DRIP VALVE	3/4"	AREA FOR DRIPLINE	5.15	44.6	58.7
17	REMOTE CONTROL DRIP VALVE	3/4"	AREA FOR DRIPLINE	6.28	46.5	60.9
18	REMOTE CONTROL DRIP VALVE	3/4"	AREA FOR DRIPLINE	1.61	67.7	62.2
19	REMOTE CONTROL DRIP VALVE	3/4"	AREA FOR DRIPLINE	11.52	47.5	62.9

SLEEVING: CLASS 200 PVC

③ ONE 6", ONE 4", ONE 2" SLEEVE

② ONE 4", ONE 2" SLEEVE

① ONE 2" SLEEVE

Maximum Flow Rate - SCH. 40 PVC Plastic Pipe	
Pipe Size	Maximum Flow (GPM)
1/2" NOT ALLOWED	
3/4"	5-7
1"	10-12
1 1/4"	16-22
1 1/2"	26-30
2"	50
2 1/2"	70

THE DESIGNS SHOWN AND DESCRIBED HEREIN (INCLUDING ALL TECHNICAL DRAWINGS, GRAPHIC REPRESENTATIONS, AND MODELS THEREOF) ARE PROPRIETARY AND CAN NOT BE COPIED, DUPLICATED, OR COMMERCIALY EXPLOITED IN WHOLE OR IN PART WITHOUT THE SOLE AND EXPRESS WRITTEN PERMISSION FROM ENVIRONMENTAL PLANNING GROUP GROUP (EPG).

ENVIRONMENTAL PLANNING GROUP (EPG) PROVIDED QUANTITIES ARE CALCULATED BASED ON THE 3D MODEL PROGRESS. CONTRACTORS ARE RESPONSIBLE FOR REVIEWING THE DESIGN AND PROVIDING THEIR OWN CALCULATIONS AND AREAS FOR THE PURPOSES OF COST ESTIMATING / BIDDING.

THE CLIENT, AND/OR THE CLIENT'S CONTRACTOR, IS RESPONSIBLE FOR ATTAINING C
PROVIDING THE NECESSARY CONSTRUCTION PERMIT FOR CITY CODE COMPLIANCE.

8/2/2024

Reserved for permit stamp

project: **SOMMET BLANC RESIDENCE 1**

White Summit Development, LLC
PO Box 980022
Park City, Utah 84098

Acoustic Consultant
BRC Acoustics
1932 1st Ave, Suite 620
Seattle, WA 98101

Pool Consultant
Cloward H2O
2698 N University Ave, Suite 290
Provo, UT 84604

Landscape Architect
EPG Design
6949 South High Tech Drive, Suite 100
Midvale, Utah 84047

Specifications Writer
Friday Group
88 Mainelli Road
Middlebury, VT

Code Consultant
Holmes
600 1st Avenue, Suite 2
Seattle, WA 98104

Fire Protection Engineer
Jensen Hughes
One Research Drive, Suite 200
Westborough, MA 01581

Vertical Transportation Consultant
Lerch Bates
19515 North Creek Parkway, Suite 3
Bothell, WA 98011

Structural Engineer
Magnusson Klemencic Associates
1301 5th Ave, Suite 3200
Seattle, WA 98101

Lighting Designer
O-
1319 SE MLK Blvd, Suite 210

Building Envelope Consultants
RDH
2101 N 34th St


Accessibility Consultant
Studio Pacifica
2144 Westlake Ave N, Suite

MEP Engineer
WSP USA
1001 Fourth Ave., Suite 3100

David

project manager Grant Hardy
drawn by Grant Hardy

job no. 20052
date June 10, 2024

 IFC 2.5/17/2024
 WUI Updates 7/29/2020

PERMIT SET

June 10, 2024

ROOF IRRIGATION

L704
