


- A. REFER TO M2.4 SERIES FOR ENLARGED PLANS.
- B. FIREPLACE FLUE ROUTING SHOWN FOR REFERENCE. REFER TO ENLARGED UNIT PLANS FOR ROUTING AND SIZING DETAIL.
- C. MECHANICAL EQUIPMENT SHOWN FOR REFERENCE. REFER TO ENLARGED UNIT PLANS FOR DETAIL.

- 1 36-INCH TALL LOUVER FOR ASPH AIR INTAKE PROVIDED AROUND TOP OF ENTIRE MECHANICAL WELL. SEE ARCHITECTURAL DRAWINGS FOR DETAIL.
- 2 FIREPLACE FLUE TERMINATIONS TO BE CAPPED WITH ORTAL VERTICAL POWER VENT PER M5.05 DETAIL 4
- 3 5"Ø FIREPLACE FLUE TERMINATION TO BE CAPPED WITH ORTAL VERTICAL POWER VENT PER M5.07 DETAIL 7.
- 4 EXHAUST FANS TO TERMINATE IN ARCHITECTURAL CEILING CAVITY IN ROOFTOP WELL. EXHAUST TERMINATIONS TO BE LOCATED 1'-0" ABOVE MECHANICAL ROOM CEILING. REFER TO M4.04 DETAIL 1 AND M4.04 DETAIL 5.



159 South Jackson St, Suite 800  
Seattle, Washington 98104 USA  
+1 206 624 5670 [olsonkundig.com](mailto:olsonkundig.com)

Olson Kundig

project:  
**SOMMET BLANC**  
9300 Marsac Ave (B2 East Parcel)  
Park City, Utah 84060



**Aspen Group USA, LLC**  
PO Box 980022  
Park City, Utah 84098

**Pool Consultant**  
**Cloward H2O**  
2696 N University Ave, Suite 290  
Provo, UT 84604

**Landscape Architect**  
**EPG Design**  
6949 South High Tech Drive, Suite 100  
Midvale, Utah 84047

Specifications Writer  
**Friday Group**  
88 Mainelli Road  
Middlebury, VT

Code Consultant  
**Holmes**  
600 1st Avenue, Suite 200A  
Seattle, WA 98104

Fire Protection Engineer  
**Jensen Hughes**  
One Research Drive, Suite 305C  
Westborough, MA 01581

Vertical Transportation Consultant  
**Lerch Bates**  
19515 North Creek Parkway, Suite 304  
Bothell, WA 98011

**Structural Engineer**  
**Magnusson Klemencic Associates**  
1301 5th Ave., Suite 3200  
Seattle, WA 98101

Lighting Designer  
O-  
1319 SE MLK Blvd, Suite 210  
Portland, Oregon 97219

**Building Envelope Consultant**  
**RDH**  
2101 N 34th St  
Seattle, WA 98103

Accessibility Consultant  
**Studio Pacifica**  
2144 Westlake Ave N, Suite F  
Seattle, WA 98109

**MEP Engineer**  
**WSP USA**  
1001 Fourth Ave., Suite 3100  
Seattle, WA 98154

principal architect \_\_\_\_\_  
project manager \_\_\_\_\_  
drawn by \_\_\_\_\_  
checked by Chacker \_\_\_\_\_  
job no. \_\_\_\_\_  
date 5/31/2024

revisions:

| no. | date | by |
|-----|------|----|
|-----|------|----|

IFC Set 3 of 3  
5/31/2024

TOWER A - ROOF  
MECHANICAL DUCT  
PLAN

M2.2A.R