

A. REFER TO M2.4 SERIES FOR ENLARGED PLANS.
B. FIREPLACE FLUE ROUTING SHOWN FOR REFERENCE. REFER TO ENLARGED UNIT PLANS FOR ROUTING AND SIZING DETAIL.
C. MECHANICAL EQUIPMENT SHOWN FOR REFERENCE. REFER TO ENLARGED UNIT PLANS FOR DETAIL.

- 1 36-INCH TALL LOUVER FOR ASPH AIR INTAKE PROVIDED AROUND TOP OF ENTIRE MECHANICAL WELL. SEE ARCHITECTURAL DRAWINGS FOR DETAIL.
- 2 FIREPLACE FLUE TERMINATIONS TO BE CAPPED WITH ORTAL VERTICAL POWER VENT PER M5.05 DETAIL 4
- 3 5"Ø FIREPLACE FLUE TERMINATION TO BE CAPPED WITH ORTAL VERTICAL POWER VENT PER M5.07 DETAIL 7.
- 4 EXHAUST FANS TO TERMINATE IN ARCHITECTURAL CEILING CAVITY IN ROOFTOP WELL. EXHAUST TERMINATIONS TO BE LOCATED 1'-0" ABOVE MECHANICAL ROOM CEILING. REFER TO M4.04 DETAIL 1 AND M4.04 DETAIL 5.

