

A. REFER TO M24 SERIES FOR ENLARGED PLANS.  
B. FIREPLACE FLUE ROUTING SHOWN FOR REFERENCE. REFER TO ENLARGED UNIT PLANS FOR ROUTING AND SIZING DETAIL.  
C. MECHANICAL EQUIPMENT SHOWN FOR REFERENCE. REFER TO ENLARGED UNIT PLANS FOR DETAIL.

1 STAIR TO BE PROVIDED WITH 2-HR RATED CEILING  
2 FIREPLACE FLUE TERMINATIONS TO BE CAPPED WITH ORTAL VERTICAL POWER VENT PER M5.05 DETAIL 4  
3 EXHAUST FANS TO TERMINATE IN ARCHITECTURAL CEILING CAVITY IN ROOFTOP WELL. EXHAUST TERMINATIONS TO BE LOCATED 1'-0" ABOVE MECHANICAL ROOM CEILING. REFER TO M4.04 DETAIL 1 AND M4.04 DETAIL 5.

