


1 TOWER B - PARKING LEVEL 1 - FA
1/8" = 1'-0"

- KEYNOTES:**
- 1 FIRE ALARM TERMINAL CABINET WITHIN 2-HR RATED SHUT ACCESSIBLE VIA 2-HR RATED ACCESS PANEL. COORDINATE INSTALLATION AND ACCESS WITH DIVISION 25.
 - 2 NO FATC THIS LEVEL.
 - 3 ACCESSORY CABINET ENCLOSURE FOR SMOKE CONTROL FAN INTERFACE LOCATED IN 2-HR RATED ENCLOSURE ADJACENT TO FAN VFD FOR FANS SPFL P1-1 THRU SPFL P1-4. REFER TO DETAIL S ON FAT 01 FOR ADDITIONAL INFORMATION. MODULES SHALL BE CONNECTED TO 2-HR DEDICATED SLC FROM BUILDING B FACU.
 - 4 STAR PRESSURIZATION FAN DUCT DETECTOR.



Reserved for permit stamp

100 South Jackson St., Suite 800
Seattle, Washington 98104 USA
+1 206 834 3870 olsonkundig.com

Olson Kundig

project
SOMMET BLANC - AB
DEER VALLEY, UTAH

ASPEN GROUP
Aspen Group USA, LLC
PO Box 980022
Park City, Utah 84098

Pool Consultant
Cloward H2O

2696 N University Ave., Suite 290
Provo, UT 84604

Landscape Architect
EPG Design

6948 South High Tech Drive, Suite 100
Midvale, Utah 84047

Specifications Writer
Friday Group

80 Mainelli Road
Middlebury, VT

Code Consultant
Holmes

600 1st Avenue, Suite 200A
Seattle, WA 98104

Fire Protection Engineer
Jensen Hughes

One Research Drive, Suite 305C
Westborough, MA 01581

Vertical Transportation Consultant
Larch Bates

19515 North Creek Parkway, Suite 304
Bothell, WA 98011

Structural Engineer
Magnusson Klemencic Associates

1301 5th Ave., Suite 3200
Seattle, WA 98101

Lighting Designer
O-

1319 SE MLK Blvd, Suite 210
Portland, Oregon 97219

Building Envelope Consultant
RDH

2101 N 34th St
Seattle, WA 98103

Accessibility Consultant
Studio Pacifica

2144 Westlake Ave N, Suite F
Seattle, WA 98109

MEP Engineer
WSP USA

1001 Fourth Ave., Suite 3100
Seattle, WA 98154

principal architect _____
project manager _____ JCC
drawn by _____ CRS, SMK
checked by _____ Checker
job no. 2052
date 05/17/2024

revisions:

A 05/08/25 ASI-012 - JH

no. date by

IFC Set 2 of 3
05/17/2024

FIRE ALARM PLAN -
TOWER B - LVL P1

FA2.2B.03

